

DATE: 10/28/2020

CLARIFICATION NO. 1
TO
CONSTRUCTION DOCUMENTS
FOR PROJECT NO. E008302

DESCRIPTION: **AML SITE 2084, FIREPIT #2**

LOCATION: **PIKE COUNTY, INDIANA**

FOR AGENCY: **DEPARTMENT OF NATURAL RESOURCES**

The information contained in this Clarification is intended to correct any composition errors and serve to eliminate any misunderstanding of the basic plans and specifications the same as if being originally incorporated therein.

ITEM NO. 1: A description of the beaver exclusion fence shown on page 5 of the Plans is as follows: Cattle panels shall be 6 feet X 16 feet with a 6-inch mesh. Tee Posts shall be at least 7 feet long and placed 8 feet on center. Ground directly under the panels shall be graded such that the panels meet the ground along the full length.

END OF CLARIFICATION