

DATE: AUGUST 15TH, 2019

CLARIFICATION NO. 1
TO
CONSTRUCTION DOCUMENTS
FOR PROJECT NO. E008304

DESCRIPTION: **AML SITE 345, LINTON NO. 1**

LOCATION: **GREENE COUNTY, INDIANA**

FOR AGENCY: **DEPARTMENT OF NATURAL RESOURCES**

The information contained in this Clarification is intended to correct any composition errors and serve to eliminate any misunderstanding of the basic plans and specifications the same as if being originally incorporated therein.

ITEM NO. 1:

Additional compacted aggregate is included in the Schedule of Base Bid Quantities to be used at the discretion of the Engineer to facilitate dependable access to the site and work in the staging area. This additional quantity would not be enough to place compacted aggregate along the entire access route and the entire staging area.

ITEM NO. 2:

The required depth of overexcavation below design grade in unsuitable material removal areas shall be based on the existing grades in the CAD file, the unsuitable material removal depth notes on the plans, and the bottom elevations in the information tables on Sheet 7. In general, based on the items mentioned above, the average overexcavation depths in the bottoms of the sediment ponds and wetlands are as follows:

Sediment Pond 1	1.8 feet
Sediment Pond 2	1.3 feet
Sediment Pond 3	0.4 feet
Anaerobic Wetland 1	0.6 feet
Anaerobic Wetland 2	0.6 feet

Unsuitable material removal may be higher in areas of berm construction. Removal of the unsuitable material may be by a combination of displacement and overexcavation.

The "Sediment Pond Information" table on Sheet 7 has errors in the "Bottom of Pond Elev." column. Please see Addendum No. 1.

END OF CLARIFICATION