

Date: June 8, 2018

**ADDENDUM NO. 1**  
**TO**  
**PLANS AND SPECIFICATIONS**  
**FOR**  
**PROJECT NO. ENG1903745010**

**DESCRIPTION OF PROJECT:** Campground B-Loop Flush Building Improvement 2018

**LOCATION:** Whitewater Memorial State Park

**ISSUE DATE:** June 8, 2018 *MSM*

**INDIANA STATE AGENCY:** DEPARTMENT OF NATURAL RESOURCES

**The information contained in this Addendum shall become a part of the basic Specifications, the same as if originally incorporated therein. The original Specifications shall remain in their entirety, except as modified by this Addendum. The items herein shall supersede information in the Specifications.**

The following items reflect clarifications to the Plans-Specifications for the bid of this project.

**ITEM NO. 1:** Specifications Section 5 Materials, Part U. Plumbing, paragraph 6.

**Delete:** “A automatic compensating valve (Type T/P) under ASSE 1016 shall be provided at each individual shower and lavatory fixture that supply tempered water through the supply piping.”

**Add:** “Provide an ASSE 1070 water temperature limiting device at all hot water sources. Provide an ASSE 1016 Type P automatic compensating valve at each shower unit.”

**The sign in sheet from the June 7, 2018 Pre-Bid Meeting is attached.**

**END OF ADDENDUM**

**State Form 21208R4**

**DAPW -118**

