

SEP 1 4 2018

LEGAL AND CODE **SERVICES**

INSTRUCTIONS:

- Only a TYPED copy will be accepted.
 Dashed line through material to be deleted; <u>underline</u> or bold face material to be added.
- 3. Use a second sheet for any material requiring more space.
- 4. Return this completed form to: Indiana Department of Homeland Security, Code Services, 402 West Washington Street, Room W246, Indianapolis, Indiana 46204.



FOR OFFICE USE ONLY	
Received 9/14/20/8 Code ASME A17.1-2016 Proposal	number # 26
Code title A17.1 Safety Code for Elevators and Escalators	Edition 2016
Section number and title 8.6 Maintenance, Repair, Replacement, and Testing	Page number 335
Proponent Representing (if applicable) AHJ	L.
Address (number and street, city, state, and ZIP code)	Telephone number (317) 232-2670
PROPOSED CODE CHANGE (check one)	
Change to read as follows Add to read as follows Delete and substitute as follows 8.6.1.3 Maintenance Personnel. Maintenance, repairs replacements, and tests shall be performed only by elevator personnel (see Section 1.3). Add to read as follows 8.6.1.3 Maintenance Personnel. Maintenance, repairs replacements, and tests shall be performed only by elevator personnel (see Section 1.3). Maintenance Personnel Shall possess a valid current State of Indiana Elevator Mechanics License and Wa a current State of Indiana Elevator Contractor license.	Delete without substitution ork for an elevator contractor that has
REASON STATEMENT AND FISCAL IMPACT	
No Fiscal impact	
	*1 <i>y</i>
Approve	
Reject	×
Approve as amended	
Further study	



SEP 1 4 2018

LEGAL AND CODE **SERVICES**

- INSTRUCTIONS: 1. Only a TYPED copy will be accepted.
 - Dashed-line through material to be deleted; <u>underline</u> or bold face material to be added.
 Use a second sheet for any material requiring more space.

 - 4. Return this completed form to: Indiana Department of Homeland Security, Code Services, 402 West Washington Street, Room W246, Indianapolis, Indiana 46204.



Received 9/14/2	2018 Code ASI	ME A		Proposal number	#27
,	1				
	Elevators and Escalators	S		Edition	2016
	nir, Replacement,and Tes	sting		Page n	number 335
Proponent Gary Herrington			presenting (<i>if applicable</i>) \HJ	7	
Address (number and street, city, state	, and ZIP code)				none number 17) 232-2670
	PROPOSE	ED CODE CHA	NGE (check one)		
Change to read as follows Add to read as follows Delete and substitute as follows Delete without substitution 8.6.1.4 Maintenance Records. Maintenance records shall document compliance with Section 8.6. Instructions for locating the maintenance records of each unit, for viewing on-site, shall be posted on the controller or at the means necessary for test (see 2.7.6.4). The provided instructions shall be permanently legible with characters a minimum of 3 mm (0.125 in.) in height. These records shall be retained for the most recent 5 yr or from the date of installation or adoption of this Code edition, whichever is less or as specified by the authority having jurisdiction. Existing maintenance records up to 5 yr Add to read as follows At the end of the paragraph add the following Maintenance Records shall be of hard copy or electronic format readily accessible for immediate review by the AHJ and elevator personnel.					
	REASON ST	TATEMENT AN	ID FISCAL IMPACT	100	
No Impact		-			
	REVI	IEW RECOMN	IENDATION		
Approve					
Reject	1			q ^e	
Approve as amended	· · · · · · · · · · · · · · · · · · ·				-
Further study			·		



SEP 1 4 2018

LEGAL AND CODE **SERVICES**

- INSTRUCTIONS: 1. Only a TYPED copy will be accepted.
 - Dashed-line through-material to be deleted; <u>underline</u> or bold face material to be added.
 Use a second sheet for any material requiring more space.

 - 4. Return this completed form to: Indiana Department of Homeland Security, Code Services, 402 West Washington Street, Room W246, Indianapolis, Indiana 46204.



Received 9 /14 / 2018 Code ASME A17. 1 - 2016 Proposal num	H 28			
Code title A17.1 Safety Code for Elevators and Escalators	Edition 2016			
8.6 Maintenance, Repair, Replacement, and Testing	Page number 335			
Proponent Gary Herrington Representing (if applicable) AHJ				
Address (number and street, city, state, and ZIP code)	Telephone number (317) 232-2670			
PROPOSED CODE CHANGE (check one)				
Change to read as follows Add to read as follows Delete and substitute as follows Delete without substitution 8.6.1.4.1 On-Site Maintenance Records (3) MCP records shall be viewable on-site by elevator personnel in either hard copy or electronic format acceptable to the authority having jurisdiction and shall include, but are not limited to, the following: (-c) conveyance identification (I.D.) and type Change to read as follows (-c) conveyance identification (State elevator operating certificate #.) and type of elevator (Passenger , Freight, MRL, Traction, Hydraulic etc.)				
REASON STATEMENT AND FISCAL IMPACT				
No Fiscal Impact				
REVIEW RECOMMENDATION				
Approve				
Reject				
Approve as amended	,			
Further study	. 1			



SEP 1 8 2018

LEGAL AND CODE **SERVICES**

- INSTRUCTIONS: 1. Only a TYPED copy will be accepted.
 - 2. Dashed line through material to be deleted; <u>underline</u> or bold face material to be added.

 - 3. Use a second sheet for any material requiring more space.

 4. Return this completed form to: Indiana Department of Homeland Security, Code Services, 402 West Washington Street, Room W246, Indianapolis, Indiana 46204.



Received 9 / 18 / 2018 Code ASM E A17. 1 - 2016 Proposal number # 29					
	-	-			
A17.1 Safety Code for Elevators and Escalators	Edition 2016				
Section number and title 8.6 Maintenance, Repair, Replacement, and Testing		Page number 336			
Proponent Gary Herrington	Representing (if applicable) AHJ				
Address (number and street, city, state, and ZIP code)		Telephone number (317) 232-2670			
PROPOSED CODE CHANGE (check one)					
☑ Change to read as follows ☐ Add to read as follows ☐ Dele	te and substitute as follows	lete without substitution			
8.6.1.7 Periodic Tests. The frequency of periodic tests shall be established by the authority having jurisdiction as required by 8.11.1.3.					
NOTE: Recommended intervals for periodic tests can be found in Nonmandatory Appendix N.					
Change to read as follows; 8.6.1.7 Periodic Tests. The frequency of periodic tests shall be established by the authority having jurisdiction as required by 8.11.1.3. The minimum interval for periodic tests shall be performed at the frequ NOTE: Recommended intervals for periodic tests can be found in Nonmandatory Appendix N.	ency level as listed on Nonmandatory A	appendix N.			
REASON STATEMENT	AND FISCAL IMPACT				
no fiscal impact	AND HOOKE IMI AGT				
REVIEW RECOMMENDATION					
Approve					
Reject	ı 1				
Approve as amended					
Further study					





SERVICES

- INSTRUCTIONS: 1. Only a TYPED copy will be accepted.
 - Dashed-line through-material to-be-deleted; <u>underline</u> or bold face material to be added.
 Use a second sheet for any material requiring more space.

 - 4. Return this completed form to: Indiana Department of Homeland Security, Code Services, 402 West Washington Street, Room W246, Indianapolis, Indiana 46204.



	E USE ONLY				
Received 9/18/2018 Code ASME /	77.1-2016 Proposal number # 30				
,					
Code title A17.1 Safety Code for Elevators and Escalators	Edition 2016				
Section number and title	Page number				
8.6 Maintenance, Repair, Replacement, and Testing	336				
Proponent Gary Herrington	Representing (if applicable) AHJ				
Address (number and street, city, state, and ZIP code)	Telephone number (317) 232-2670				
PROPOSED CODE (CHANGE (check one)				
The Gold Gold	TIMITOL (UNION CITC)				
8.6.1.7.1 Periodic tests shall be witnessed by an inspector employed by the authority having jurisdiction or by a person authorized by the authority having jurisdiction.	e and substitute as follows				
The inspector shall conform to the requirements in 8.11.1.1.					
Change to read as follows; 8.6.1.7.1 Periodic tests shall be witnessed by an inspector employed by the authority having jurisdiction or by a person authorized by the authority having jurisdiction. The 2.27.4.2 Phase I Emergency Recall Operation by Fire Alarm Initiating Devices tests shall be witnessed by the inspector elevator contractor. The inspector shall conform to the requirements in 8.11.1.1.	mployed by the AHJ or by a licensed elevator mechanic or licensed				
no fiscal impact	AND I ISOAL IMIFACT				
REVIEW RECOMMENDATION					
Approve					
Reject					
Annual Laboratoria de la Companyo de					
Approve as amended					
Further study					