

STRUCTURE BACKFILL

The Standard Specifications are revised as follows:

SECTION 904, BEGIN LINE 360, DELETE AND INSERT AS FOLLOWS:

904.05 Structure Backfill

The material shall be of acceptable quality, free from large or frozen lumps, wood, or other extraneous matter. It shall consist of suitable sand, gravel, crushed stone, ACBF, or GBF. ~~Coarse aggregate used for backfilling end bents on beam structures shall be No. 8 or No. 9 crushed stone or BF slag, class D or higher, in accordance with 904.~~ Structure backfill shall be in accordance with one of the following gradations *or No. 8, No. 9, No. 11, No. 53, or No. 73 coarse aggregate in accordance with the gradation requirements of 904.03(e). Coarse aggregate No. 8, No. 9, No. 11, No. 53, or No. 73 shall be crushed stone or ACBF, class D or higher.*

ARCHIVED