



INDIANA UTILITY REGULATORY COMMISSION
101 W. WASHINGTON STREET, SUITE 1500E
INDIANAPOLIS, INDIANA 46204-3407

<http://www.in.gov/iurc>
Office: (317) 232-2701
Facsimile: (317) 232-6758

Pipeline Safety Division Investigation Report

Investigation regarding: Miller Pipeline

UPPAC Database Record ID: 3618

Report Date: 6/26/2013

Investigator: Mike Orr

Damage Date: 8/23/2012 3:27:38 PM

Damage Address: 202 E Gilbert St, Muncie, Delaware

The Parties

Excavator: **Miller Pipeline**

Address: 8850 Crawfordsville Rd, Indianapolis, In 46234

Facility Owner: **Vectren**

Pipeline Facility

Facility Type: Natural Gas

Facility Function: Service/Drop

Type of Equipment: Backhoe/Trackhoe

Type of Work Performed: Natural Gas

Damage Impact

Product Release: Yes

Ignition: No

Service Interruption: False

Number of Customers Affected: 0

Injuries: 0

Fatalities: 0

Repair Cost (if known): \$395

Excavator Activities/Cause of Damage Information:

Excavator Request Locates: Yes

Indiana 811 Ticket Number: 1208070517

Original Start Date:

Locate Instructions:

Follow-Up Locate Instructions (if applicable):

Synopsis: Excavator struck and damaged an unknown underground live natural gas stub while performing work for operator.

Findings: Reported by Indiana 811; excavator's response to initial notice was received on 10/12/2012. The excavator had a valid locate and damaged a live unknown natural gas stub while working on operator's facilities due to a lack of accurate operator maps and records.

Conclusion: There was a failure to provide an accurate facility locate by the gas operator

Violation: IC 8-1-26-18(f) Operator failed to locate or provided incorrect locate markings.



INDIANA UTILITY REGULATORY COMMISSION
101 W. WASHINGTON STREET, SUITE 1500E
INDIANAPOLIS, INDIANA 46204-3407

<http://www.in.gov/iurc>
Office: (317) 232-2701
Facsimile: (317) 232-6758

September 18, 2012

Ms. Darlene Kulhanek
Vectren
1 N Main Street
Evansville, IN 47702

Subject: Investigation Request for Information

Date of Event: 8/23/2012

Event Location: 202 E Gilbert St, Muncie

Facility Owner: Vectren

Excavator: Miller Pipeline

Other Party: N/A

Pipeline Division Case No. 3618

Dear Ms. Kulhanek:

Pursuant to Indiana Code 8-1-26, the *Indiana Damage to Underground Facilities Act*, the Pipeline Safety Division of the Indiana Utility Regulatory Commission ("Pipeline Division") is required to investigate reported incidents of alleged statutory violations involving underground pipeline safety. The purpose of this statute is to promote excavation and pipeline safety and to reduce the imminent danger to life, health, property, or loss of service associated with unsafe digging practices. Please note that the investigation does not entail determining criminal liability or a civil determination of fault or damages; however, it does determine whether any statutory violations were committed regarding public safety.

The Pipeline Division received information regarding potential statutory violations regarding the date and location referenced above. You were identified as a person or entity that might have information that would assist the Pipeline Division in its investigation. Therefore, we have contacted you in order to receive the full account of information in order to make a fair determination related to the circumstances of this incident.

We have asked all involved parties, entities and witnesses to provide *written* information within *30 days* in order to meet legal deadlines to conclude our investigation. **Please consider this letter as a formal request to receive any and all information and evidence (including a narrative, documentation, maps, photographs or any other written information) you can access regarding anything you may know about the incident referenced above.**



DAMAGE INFORMATION REPORT -- PIPELINE SAFETY DIVISION

State Form 54122 (R2 / 7-11)
INDIANA UTILITY REGULATORY COMMISSION

Submitted to IURC-Pipeline Safety on: 10-5-2012

Who is submitting this information?

Name of person providing this information: Darlene Kulhanek

Business address (*number and street*): 1 Main Street

City, State, and ZIP code: Evansville, IN 47711

Telephone number (*area code*): 812-491-4227

Fax number (*area code*): 812-491-4504

E-mail address: dkulhanek@vectren.com

Excavator Information, if known

Full name: Miller Pipeline

Business address (*number and street*): 8850 Crawfordsville Rd (Box 34141)

City, State, and ZIP code: Indianapolis, IN 46234

Telephone number (*area code*): 317-295-6417

Fax number (*area code*): 317-295-6418

E-mail address: Unknown

Excavation or Demolition Information

Excavator type: Contractor

Excavation or demolition equipment: Backhoe/Trackhoe

Type of work performed: Natural Gas

Date and Location of Damage

Date of damage (month, day, year): 8-23-2012

County: Delaware

City: Muncie

Street address (number and street, city, state, and ZIP code):
202 E Gilbert Street, Muncie, IN

Nearest intersection: Same

Right of way where damage occurred: Public - City Street

Was there a release of product? Yes

If yes, was there an ignition of product? No

Were evacuations necessary as a result of release? No

If yes, how many evacuated? 0

Was there a customer service interruption? Yes

If yes, how many affected? 0

Time to restore service (in hours): 0

Enter number of injuries, if applicable and known: 0

Enter number of fatalities, if applicable and known: 0

Property damage, Estimate \$ 395.15

Affected Facility Information

What type of pipeline was damaged? Natural Gas

What was the affected facility? Service/Drop

What was the depth of the facility, in inches?

Notification, Locating, Marking

Did excavator request locates prior to commencing work? Yes

Enter Indiana 811 ticket number, if known: 1208070517

Was the locate request completed within two working days? Yes

If locates were performed, were they done so by a contractor or pipeline employee? Contract Locator

If a contractor locator, enter the company name, if known: USIC

Were facility marks visible in the area of excavation? Yes

Were facilities marked correctly? No

Type of markings used: Paint and Flags

If other, please specify: Unknown

Was site marked by "White Lining"? No

Were special instructions part of the locate request? Unknown/Other

Were maps used to complete the locate request? Unknown/Other

Were pipeline company representatives on site during excavation? No

Did the excavator notify the operator in the event of this damage? Yes

Did the excavator notify Indiana 811 in the event of this damage? Yes

Did the excavator notify 911 in the event of a release of product? Unknown/Other

Description of Cause

Select from the list the most accurate cause for the damage: Abandoned facility

Additional Comments

1" steel service severed by hoe. Stub.

Miller Pipeline

FACILITIES DAMAGE REPORT GAS

Task No.: 103.0510

Capital (O&M circle one)

FDS 0016777

FACILITY TYPE

- DISTRIBUTION
PROPANE
SERVICE
STORAGE
TRANSMISSION (include supplemental report)

TIME OCCURRED: 2:45 AM/PM
TIME FOUND: 2:45 AM/PM

DATE OF DAMAGE: 8/23/12
Cost Center No.: 5733

DAMAGE SITE ADDRESS: 802 E Gilbert St LOT #

COUNTY Delaware CITY: Muncie STATE: IN TOWNSHIP Cen

Table with columns: FACILITIES DAMAGED, ORIFICE SIZE(S), (1), (2), (3). Rows include Farm Tap, Heater, Main, Meter Residential, etc.

- VISUAL OBSERVATION AT DAMAGE SITE
VISUAL OBSERVATION ABOVE GROUND
LOCATE APPLICABLE?
FACILITIES PROPERLY MARKED
MARKING METHODS
LOCATOR ERROR

Table with columns: TYPE OF MATERIAL, DAMAGE TYPE, PRESSURE. Rows include Cast Iron, Plastic, Steel, etc.

PROTECTION IN PLACE
BUILDING FENCE NONE
POST RAIL VAULT N/A

LEAK REPORT NUMBER #12897
EFV ACTIVATED YES NO

FEED TYPE
ONE-WAY FEED
TWO-WAY FEED

SERVICE ORDER # NA

Table with columns: DAMAGED BY, TYPE OF CONSTRUCTION. Rows include Contractor, County, Developer, etc.

WORKING FOR
CITY COUNTY DEVELOPER
PROPERTY/OWNER STATE
UTILITY

COMPANY REPRESENTATIVE ON SITE YES NO
OBSERVATION BY: Kuester
NAME OF LOCATOR: Nathan Buck
LOCATING ORGANIZATION: USC

COPY OF MARKOUT REQUEST PROVIDED WITHIN 2 WORKING DAYS
YES NO N/S

Damage # 1208232536
NOTIFICATION AND OTHER DETAILS OF LOCATE
LOCATE TICKET #: 1208211417
DATE: 8-21-12 TIME: 10:30 AM/PM

CONTACT NAME:
TIME CALLED:
TIME LOCATOR ARRIVED AT SITE: AM/PM

LOCATE COMPANY NOTIFIED YES NO N/S
COMPANY NOTIFIED OF LOCATE NEAR CRITICAL FACILITIES
ONE CALL CENTER
IUPPS
OUPS
UNKNOWN

TYPE OF EQUIPMENT

- AUGER
- BACKHOE/TRACKHOE
- BORING
- DRILLING
- EXPLOSIVES
- FARM EQUIPMENT
- GRADER/SCRAPER
- HAND TOOLS
- MILLING EQUIPMENT
- PLOW
- PROBING DEVICE
- TRENCHER
- VACUUM EQUIPMENT
- VEHICLE

IF OTHER _____

DAMAGING CAUSE

- ABANDON FACILITY
- DETERIORATED FACILITY
- FACILITY COULD NOT BE FOUND/LOCATED
- FACILITY WAS NOT LOCATED/MARKED
- FAILURE TO MAINTAIN CLEARANCE
- FAILURE TO MAINTAIN MARKS
- FAILURE TO SUPPORT EXPOSED FACILITY
- FAILURE TO USE HAND TOOLS WHERE REQ
- IMPROPER BACKFILLING
- INCORRECT RECORDS/MAPS
- MARKING OR LOCATIONS NOT SUFFICIENT
- NO NOTIFICATION MADE TO ONE-CALL CENT
- ONE-CALL NOTIFICATION ERROR
- PREVIOUS DAMAGE
- WRONG INFORMATION PROVIDED

IF OTHER _____

DID EXCAVATOR NOTIFY YOU? YES NO

EVACUATION REQUIRED? YES NO

MEDIA AT SITE? YES NO

WAS THERE IGNITION OF GAS? YES NO

INVOICE: YES NO N/S

DAMAGING PARTY NAME: Miller Pipeline

ADDRESS: Po Box 34141

CITY/STATE/ZIP: Indianapolis In 46234-0141

PHONE NUMBER: Ph 317-293-0278

PREPARED BY: Kurtz DATE: 8-23-12

CONTRACTOR REPAIRS

- CONTRACTOR WORKING FOR VECTREN MADE REPAIRS AT OWN EXPENSE
 - YES NO N/S
- CONTRACTOR REPAIRED DAMAGE
 - YES NO N/S

NAME OF CONTRACTOR: Miller Pipeline

OF REGULAR HOURS _____

OF OVERTIME HOURS _____

OF REGULAR HOURS _____

CREW TYPE: Unit Footage

MATERIALS OR ROAD WORK

- METER WAS REPLACED _____ (STORES CODE)
- REGULATOR WAS REPLACED _____ (STORES CODE)
- TEMPORARY ASPHALT REPAIR _____ (SQ.FT.)
- PERMANENT ASPHALT REPAIR _____ (SQ.FT.)

RIGHT OF WAY

- DEDICATED UTILITY EASEMENT
- FEDERAL UTILITY EASEMENT
- PIPELINE
- POWER/TRANSMISSION LINE
- PRIVATE - BUSINESS
- PRIVATE - EASEMENT
- PRIVATE - LAND OWNER
- PUBLIC - COUNTY ROAD
- PUBLIC - INTERSTATE HIGHWAY
- PUBLIC - OTHER
- PUBLIC - STATE HIGHWAY
- PUBLIC - CITY STREET
- UNKNOWN

PARTY TO INVOICE NAME: _____

ADDRESS: _____

CITY/STATE/ZIP: _____

PHONE NUMBER: _____

REVIEWED BY FIELD SUPERVISOR: _____ DATE: 8-28-12

*Self Inflicted Damage by MPL
Miller MADE All Repairs*

SB, 8-28-12

NORMAI, NOTICE

Ticket : 1208070517 Date: 08/07/2012 Time: 08:33 Oper: SARAH.HEMINGER Char.:000

State: IN Cnty: DELAWARE Twp: CENTER
 Cityname: MUNCIE Inside: Y Near: N
 Subdivision:

Address : 202
 Street : E GILBERT ST
 Cross 1 : JEFFERSON ST Within 1/4 mile: Y
 Location: PAINT AND FLAG ENTIRE PROPERTY OF 202 208 210 220 222 E GILBERT ST AND
 ALONG E GILBERT ST
 :
 Grids : 4011B8523D 4011A8523D

Work type : REPLACE GAS SERVICE
 Done for : VECTREN
 Start date: 08/09/2012 Time: 09:00 Hours notice: 48/48 Priority: NORM
 Ug/Oh/Both: U Blasting: N Boring: N Railroad: N Emergency: N
 Duration : 1 WEEK Depth: 4FT

Company : MILLER PIPE LINE Type: CONT
 Co addr : 8850 CRAWFORDSVILLE RD
 City : INDIANAPOLIS State: IN Zip: 46234
 Caller : SARAH HEMINGER Phone: (317)295-6417
 Contact : HAROLD Phone:
 BestTime:
 Mobile : (317)800-9471
 Fax : (317)295-6418
 Email : SARAH.HEMINGER@MILLERPIPELINE.COM

Remarks : All tickets are taken and processed on Eastern Daylight Time
 Will you be white-lining the dig site area? NO
 :

Submitted date: 08/07/2012 Time: 08:33
 Members: AEPIN ID1205 ID1256 ID3347 ID4245 ID9979 SBCIN SM

Member Name	Facility Types
AMERICAN ELECTRIC POWER	ELECTRIC
AT&T - DISTRIBUTION	COMMUNICATIONS
COMCAST CABLE- MUNCIE	CABLE TV
IN AMERICAN WATER MUNCIE	WATER
MUNCIE SANITARY DISTRICT ENGINEERING	
PAETEC / FORMERLY MCCLEOD USA	FIBER OPTIC
VECTREN - MUNCIE	GAS

[View Map](#)

[Close Map](#)

DAMAGE, DAMAGE

Ticket : 1208232536 Date: 08/23/2012 Time: 15:23 Oper: SPEOPLES Chan:036

State: IN Cnty: DELAWARE Twp: CENTER
 Cityname: MUNCIE Inside: Y Near: N
 Subdivision:

Address : 202
 Street : E GILBERT ST
 Cross 1 : JEFFERSON ST Within 1/4 mile: Y
 Location: PAINT AND FLAG ENTIRE PROPERTY OF 202 208 210 220 222 E GILBERT ST AND
 ALONG E GILBERT ST
 :
 Grids : 4011B8523D 4011A8523D

Work type : REPLACE GAS SERVICE
 Done for : VECTREN
 Start date: 08/23/2012 Time: 15:24 Hours notice: 0/000 Priority: EMER
 Ug/Oh/Both: U Blasting: N Boring: N Railroad: N Emergency: Y
 Duration : 1 WEEK Depth: 4FT

Company : MILLER PIPE LINE Type: CONT
 Co addr : 8850 CRAWFORDSVILLE RD
 City : INDIANAPOLIS State: IN Zip: 46234
 Caller : DUSTIN ADDISON Phone: (317)295-6417
 Contact : HAROLD Phone:
 BestTime:
 Mobile : (317)800-9471
 Fax : (317)295-6418
 Email : SARAH.HEMINGER@MILLERPIPELINE.COM

Remarks : All tickets are taken and processed on Eastern Daylight Time
 PER DUSTIN ADDISON - GAS LINE IS DAMAGED - GAS LINE IS BLOWING AND CAN BE SMELT
 AND HEARD - HAVE NOT CALLED 911 - ADVISED TO CALL 911 - VECTREN IS THE UTILITY -
 LINE WAS DAMAGED IN THE ROAD INFRONT OF 202 E GILBERT - DESCRIPTION OF LINE IS 1
 INCH STEEL AND SILVER IN COLOR - CREW IS ON SITE - VECTREN HAS BEEN CALLED AND
 IS ON SITE - PREVIOUS TICKET 1208070517 - THANK YOU
 Will you be white-lining the dig site area? NO
 :

Submitted date: 08/23/2012 Time: 15:23
 Members: AEPIN ID1205 ID1256 ID3347 ID4245 ID9979 SBCIN SM

Member Name	Facility Types
AMERICAN ELECTRIC POWER	ELECTRIC
AT&T - DISTRIBUTION	COMMUNICATIONS
COMCAST CABLE- MUNCIE	CABLE TV
IN AMERICAN WATER MUNCIE	WATER
MUNCIE SANITARY DISTRICT ENGINEERING	
PAETEC / FORMERLY MCCLEOD USA	FIBER OPTIC
VECTREN - MUNCIE	GAS

[View Map](#) | [Close Map](#)



Property of United States Infrastructure Corporation
Photo taken on 8/23/2012 4:28:40 PM



Property of United States Infrastructure Corporation
Photo taken on 8/23/2012 4:37:44 PM



Property of United States Infrastructure Corporation
Photo taken on 8/23/2012 4:46:18 PM

Service Order Status

Monday, September 10, 2012

Enter Service Order Number:

5347809



Clear Form

Refresh Data

Banner Instance: CS03PROD CS01PROD CS02PROD

Order Number: N5347809

Order Type: LEAK

Order Status: Completed

Customer: 620002895 - MUNCIE PROPERTIES

Prem: 5487313 - 202 E GILBERT ST UNIT HSMTR

Technician: 2679 - Kurtz, Jeff

Order Dates and Times

Need Date: 8/23/2012 4:34:00 PM
Time Created: 8/23/2012 3:45:27 PM
Time Dispatched: 8/23/2012 3:45:27 PM
Time In Route: 8/23/2012 4:31:00 PM
Time On-Site: 8/23/2012 4:31:16 PM
Tech Complete: 8/23/2012 5:32:10 PM
Time Closed: 8/23/2012 5:32:10 PM

Events Performed/Completion Code

LKOT - CMP

Meter Information

Current ReadStatus

Old Meter: 0 Active
New Meter:

Completion Notes

bsci project miller pipeline pulled 1" stl line out of top of 4" lp bare stl m
 ain to be retired in couple days have no idea what this line would have ever wen
 t to unlocated

Request Notes

PER BRITNEY WITH INDIANA 811 MILLER PIPELINE HAS HIT A GAS LINE IT IS BLOWING/1 INCH STEELE LINE /
 XST JEFFERSON/ FRONT OF PROPERTY/ LOCATE #1208232536/POC DUSTIN ADDISON WITH MILLER PIPELINE 317-800
 -9471

MDSI Event Dates and Times

Event	Date/Time	User
AsnAssignmentManualAck_evt	8/23/2012 4:31:00 PM	Kurtz, Jeff
AsnAssignmentEnRoute_evt	8/23/2012 4:31:00 PM	Kurtz, Jeff
AsnAssignmentOnSite_evt	8/23/2012 4:31:16 PM	Kurtz, Jeff
OrdOrderComplete_evt	8/23/2012 5:32:10 PM	Kurtz, Jeff

NOTE:The Reporting database replicates in near real-time; it has been approximately 1 minute(s) since the last transaction replicated.



INFORMATION REQUEST

State Form 54909 (2-12)

INDIANA UTILITY REGULATORY COMMISSION – PIPELINE SAFETY DIVISION

Case Number: 3618

The Pipeline Safety Division of the Indiana Utility Regulatory Commission requests any and all information you can provide regarding the following criteria.

Upon completion of answers select email button for submission.

The Parties

Excavator Information:

Business Name: Miller Pipeline

Responsible Party Personal Name: Harold Stonebraker

Title (if any): Foreman

Address (number and street): 8850 Crawfordsville Rd.

City, State and ZIP Code: Indianapolis, IN 46234

Preferred Telephone Number (area code): 317 293-0278

Cellular Telephone Number (area code): _____

Email Address: info@millerpipeline.com

Facility Information:

Business Name: Vectren

Responsible Party Personal Name: Jeff Kurtz

Title (if any): Inspector

Address (number and street): 1800 W. 26th Str.

City, State and ZIP Code: Muncie,IN

Preferred Telephone Number (area code): _____

Cellular Telephone Number (area code): 765 635-4387

Email Address: _____

Locator Service Information:

Business Name: USIC

Responsible Party Personal Name: Nathan Buck

Title (if any): Locator

Address (number and street): _____

City, State and ZIP Code: _____

Preferred Telephone Number (area code): _____

Cellular Telephone Number (area code): _____

Email Address: _____

Cause of Damage Information

Type of Equipment (select one): Backhoe/Trackhoe

Type of Work Performed (select one): Natural Gas

Other Information (Witness, Police, Fire, Other):

Personal Contact: Dustin Addison

Business/Organization Name: Miller Pipeline

Title (if any): _____

Address (number and street): 8850 Crawfordsville Rd.

City, State and ZIP Code: Indianapolis, IN 46234

Preferred Telephone Number (area code): 317 293-0278

Cellular Telephone Number (area code): _____

Email Address: info@millerpipeline.com

Utility Line Impact

Location of Damage:

Address (*number and street*): Gilbert and Mulberry

City, State and ZIP Code: Muncie, IN

Nearest Intersection: Gilbert and Mulberry

Product Type (*select one*): Natural Gas

Facility Type (*select one*): Distribution

Size (Diameter/etc.): 3/4"

Pressure (PSIG/Inches): 6"

Interruption in Service: Yes No Number of Customers Affected: _____

Evacuation: Yes No If yes, How Many Evacuated? _____

Repair Cost (if known): \$ 500

Release of Product: Yes No

Ignition and/or Fire: Yes No

Excavator Notify 811: Yes No

Locate Information

Excavator Request Locate: Yes No

Indiana 811 Locate Ticket Number: 1208211417

- Locate Marks Visible:** Yes No
- Locate Marks Correct:** Yes No
- Excavator "White Lined":** Yes No
- Maps Used to Mark Facilities:** Yes No
- Was Locate Provided within Two (2) Working Days:** Yes No
- Operator Employees On-site during Excavation:** Yes No
-

Incident Impact Information

Number of Outpatient Treated: ⁰ _____

Number of Inpatient Treated: ⁰ _____

Number of Fatalities: ⁰ _____

Fire Department Response: Yes No

Police Department Response: Yes No

Ambulance Response: Yes No

Additional Information / Comments

While we were installing a new 2" gas main about 4 feet away from an existing low pressure gas main, the backhoe struck an unknown and unmarked 3/4" gas (service) line that went to street corner and was dead ended there. We quickly uncovered it at the existing main and removed the old tap and repaired it with a band-clamp. This 3/4" low pressure line was not on maps and was not marked. It was likely an abandoned old street corner gas light line.

NARRATIVE STATEMENT

Your Pipeline Safety Division Case Number: 3618

Your Full Name: Ralph Miller

Full Name of Business / Entity (if applicable): Miller Pipeline

Your Business Title (if applicable): VP HR

Address (number and street): 8850 Crawfordsville Rd.

City: Indianapolis State: IN ZIP Code: 46234

Your E-mail Address: ralph.miller@millerpipeline.com

Today's Date (month, day, year): September 27, 2012

Your Signature: Ralph Miller Title (if any) VP HR

Please return your Narrative Statement to:

Pipeline Safety Division – Case Number 3618
Indiana Utility Regulatory Commission
101 West Washington Street, 1500E
Indianapolis, IN 46204

Or scan the statement and Email to:

PipelineDamageCase@urc.in.gov

Heminger-Frazier, Sarah

From: Heminger-Frazier, Sarah
Sent: Tuesday, August 07, 2012 8:42 AM
To: Stonebraker, Harold
Subject: Emailing: MessageTextPrinter.htm

[Close Window]
8/27/2012

Original ticket w/UPRS

"If you have a pencil handy, I have a ticket number to provide to you. If you need to call us back for any reason, your ticket number will assist us in locating this ticket. Are you ready for your number?"

NORMAL NOTICE

Ticket : 1208070517 Date: 08/07/2012 Time: 08:33 Oper: SARAH.HEMINGER Chan:000

State: IN Cnty: DELAWARE Twp: CENTER
Cityname: MUNCIE Inside: Y Near: N
Subdivision:

Address : 202
Street : E GILBERT ST
Cross 1 : JEFFERSON ST Within 1/4 mile: Y
Location: PAINT AND FLAG ENTIRE PROPERTY OF 202 208 210 220 222 E GILBERT ST AND
ALONG E GILBERT ST
:
Grids : 4011B8523D 4011A8523D

Work type : REPLACE GAS SERVICE
Done for : VECTREN
Start date: 08/09/2012 Time: 09:00 Hours notice: 48/48 Priority: NORM
Ug/Oh/Both: U Blasting: N Boring: N Railroad: N Emergency: N
Duration : 1 WEEK Depth: 4FT

Company : MILLER PIPE LINE Type: CONT
Co addr : 8850 CRAWFORDSVILLE RD
City : INDIANAPOLIS State: IN Zip: 46234
Caller : SARAH HEMINGER Phone: (317)295-6417
Contact : HAROLD Phone:
BestTime:
Mobile : (317)800-9471
Fax : (317)295-6418
Email : SARAH.HEMINGER@MILLERPIPELINE.COM

Remarks : All tickets are taken and processed on Eastern Daylight Time
Will you be white-lining the dig site area? NO
:

Submitted date: 08/07/2012 Time: 08:33
Members: AEPIN ID1205 ID1256 ID3347 ID4245 ID9979 SBCIN SM

Member Name	Facility Types
AMERICAN ELECTRIC POWER	ELECTRIC
AT&T - DISTRIBUTION	COMMUNICATIONS
COMCAST CABLE - MUNCIE	CABLE TV
IN AMERICAN WATER MUNCIE	WATER
MUNCIE SANITARY DISTRICT ENGINEERING	
PAETEC / FORMERLY MCCLEOD USA	FIBER OPTIC
VECTREN - MUNCIE	GAS

NORMAL NOTICE

Ticket : 1208211417 Date: 08/21/2012 Time: 10:30 Oper: SARAH.HEMINGER Chan:000

State: IN Cnty: DELAWARE Twp: CENTER
Cityname: MUNCIE Inside: Y Near: N
Subdivision:

Address :

Street : GILBERT ST
Cross 1 : MULBERRY ST Within 1/4 mile: Y
Location: PAINT AND FLAG 200FT IN ALL DIRECTION AT THE INTERSECTION OF
:
Grids : 4011B8523D 4011A8523D

Work type : REPLACE GAS MAIN

Done for : VECTREN

Start date: 08/23/2012 Time: 10:45 Hours notice: 48/48 Priority: NORM

Ug/Oh/Both: U Blasting: N Boring: N Railroad: N Emergency: N

Duration : 1 WEEK Depth: 4FT

Company : MILLER PIPE LINE Type: CONT
Co addr : 8850 CRAWFORDSVILLE RD
City : INDIANAPOLIS State: IN Zip: 46234
Caller : SARAH HEMINGER Phone: (317)295-6417
Contact : HAROLD Phone:
BestTime:
Mobile : (317)800-9471
Fax : (317)295-6418
Email : SARAH.HEMINGER@MILLERPIPELINE.COMRemarks : All tickets are taken and processed on Eastern Daylight Time
Will you be white-lining the dig site area? NO

:

Submitted date: 08/21/2012 Time: 10:30

Members: AEPIN ID1205 ID1256 ID3347 ID4245 ID9979 SBCIN SM

Member Name**Facility Types**

AMERICAN ELECTRIC POWER	ELECTRIC
AT&T - DISTRIBUTION	COMMUNICATIONS
COMCAST CABLE- MUNCIE	CABLE TV
IN AMERICAN WATER MUNCIE	WATER
MUNCIE SANITARY DISTRICT ENGINEERING	
PAETEC / FORMERLY MCCLEOD USA	FIBER OPTIC
VECTREN - MUNCIE	GAS

[View Map](#)[Close Map](#)