STATE OF INDIANA

INDIANA UTILITY REGULATORY COMMISSION
101 W. WASHINGTON STREET, SUITE 1500E
INDIANAPOLIS, INDIANA 46204-3407

http://www.in.gov/iurc
Office: (317) 232-2701
Facsimile: (317) 232-6758

Pipeline Safety Division Investigation Report

Investigation regarding: Lineal Contracting

UPPAC Database Record ID: 3152

Investigator: Howard Friend

Report Date: 8/3/2012

Damage Date: 6/7/2012 8:32:02 AM

Damage Address: 2500 E 3rd St

City: Bloomington

County: Monroe

The Parties

Excavator: **Lineal Contracting**

Contact: Ryan Sullivan

Address: 2922 Mitchell Road, Bedford, In 47421

Telephone:

Facility Owner: Vectren

Contact: Darlene Kulhanek

Address: 1 N Main Street, Evansville, IN 47702

Pipeline Facility

Facility Type: Natural Gas

Facility Function: Service/Drop

Investigation regarding: Lineal Contracting

UPPAC Database Record ID: 3152

Damage Impact

Product release: Yes

Ignition: No

Service Interruption: True

Number of Customers Affected: 1

Injuries: 0

Fatalities: 0

Repair Cost (if known): $1013.63

Excavator Activities/Cause of damage information:

Excavator request locates: Yes Indiana 811 ticket Number: 1205302980

Type of Equipment: Boring

Type of work performed: Telecommunications

Synopsis: A natural gas service facilty was damaged during boring for a telecommunications line.

Findings: Reported by Indiana 811; excavator's response to initial notice was received on 7/17/2012. Excavator had a valid locate request and the gas operator provided accurate locate markings. The excavator reported "human error" as the cause of the damage.

Conclusion: Excavator failed to maintain the required clearance with mechanized equipment.

Violation: IC 8-1-26-20(b): Failure to plan excavation to avoid damage or interference with underground facilities; Failure to maintain two (2) feet clearance with mechanized equipment.

Lineal Contracting currently has 14 other reports of damages in the record, between 8/25/2009 and 7/4/2012 5:10:52 PM.

NO

LOCATE

TICKET

PROVIDED

STATE OF INDIANA

INDIANA UTILITY REGULATORY COMMISSION
101 W. WASHINGTON STREET, SUITE 1500E
INDIANAPOLIS, INDIANA 46204-3407

http://www.in.gov/iurc
Office: (317) 232-2701
Facsimile: (317) 232-6758

July 13, 2012

Ms. Darlene Kulhanek
Vectren
1 N Main Street
Evansville, IN 47702

Subject: Investigation Request for Information

Date of Event: 6/7/2012

Event Location: 2500 E 3rd St, Bloomington

Facility Owner: Vectren

Excavator: Lineal Contracting

Other Party: N/A

Pipeline Division Case No. 3152

Dear Ms. Kulhanek:

Pursuant to Indiana Code 8-1-26, the *Indiana Damage to Underground Facilities Act*, the Pipeline Safety Division of the Indiana Utility Regulatory Commission ("Pipeline Division") is required to investigate reported incidents of alleged statutory violations involving underground pipeline safety. The purpose of this statute is to promote excavation and pipeline safety and to reduce the imminent danger to life, health, property, or loss of service associated with unsafe digging practices. Please note that the investigation does not entail determining criminal liability or a civil determination of fault or damages; however, it does determine whether any statutory violations were committed regarding public safety.

The Pipeline Division received information regarding potential statutory violations regarding the date and location referenced above. You were identified as a person or entity that might have information that would assist the Pipeline Division in its investigation. Therefore, we have contacted you in order to receive the full account of information in order to make a fair determination related to the circumstances of this incident.

We have asked all involved parties, entities and witnesses to provide *written* information within *30 days* in order to meet legal deadlines to conclude our investigation. **Please consider this letter as a formal request to receive any and all information and evidence (including a narrative, documentation, maps, photographs or any other written information) you can access regarding anything you may know about the incident referenced above.**

DAMAGE INFORMATION REPORT – PIPELINE SAFETY DIVISION

State Form 54122 (R2 / 7-11)
INDIANA UTILITY REGULATORY COMMISSION

Submitted to IURC-Pipeline Safety on: 07-19-2012

Who is submitting this information?

Name of person providing this information: Darlene Kulhanek

Business address *(number and street)*: 1 Main Street

City, State, and ZIP code: Evansville, IN 47711

Telephone number *(area code)*: 812-491-4227

Fax number *(area code)*: 812-491-4504

E-mail address: dkulhanek@vectren.com

Excavator Information, if known

Full name: Lineal Contracting

Business address *(number and street)*: 2922 Mitchell Road

City, State, and ZIP code: Bedford, IN 47421

Telephone number *(area code)*: 812-277-0477

Fax number *(area code)*: 812-275-6706

E-mail address: Unknown

Excavation or Demolition Information

Excavator type: Contractor

Excavation or demolition equipment: Boring

Type of work performed: Telecommunications

Date and Location of Damage

Date of damage (*month, day, year*): 6-7-2012

County: Monroe

City: Bloomington

Street address (*number and street, city, state, and ZIP code*):
2500E 3rd Street, Bloomington, IN

Nearest intersection: Unknown

Right of way where damage occurred: Dedicated Public Utility Easement

Was there a release of product? Yes

If yes, was there an ignition of product? No

Were evacuations necessary as a result of release? No

If yes, how many evacuated? 0

Was there a customer service interruption? Yes

If yes, how many affected? 1

Time to restore service (*in hours*): 2

Enter number of injuries, if applicable and known: 0

Enter number of fatalities, if applicable and known: 0

Property damage, Estimate $1,013.63

Affected Facility Information

What type of pipeline was damaged? Natural Gas

What was the affected facility? Service/Drop

What was the depth of the facility, in inches? _____

Notification, Locating, Marking

Did excavator request locates prior to commencing work? Yes

Enter Indiana 811 ticket number, if known: 1205302980

Was the locate request completed within two working days? Yes

If locates were performed, were they done so by a contractor or pipeline employee? Contract Locator

If a contractor locator, enter the company name, if known: USIC

Were facility marks visible in the area of excavation? Yes

Were facilities marked correctly? Yes

Type of markings used: Paint

If other, please specify: _____

Was site marked by "White Lining"? No

Were special instructions part of the locate request? Unknown/Other

Were maps used to complete the locate request? Unknown/Other

Were pipeline company representatives on site during excavation? No

Did the excavator notify the operator in the event of this damage? Yes

Did the excavator notify Indiana 811 in the event of this damage? Yes

Did the excavator notify 911 in the event of a release of product? Unknown/Other

Description of Cause

Select from the list the most accurate cause for the damage: --Failure to use hand tools where required

Additional Comments

2" plastic service severed by bore. Not hand exposed.

NOW DUE

$1,013.63

2 VECTREN ENERGY DELIVERY OF INDIANA - NORTH

LINEAL CONTRACTING
2922 MITCHELL ROAD,
BEDFORD, IN 47421

Type: GAS
Invoice: FDS0016352
BillToID: 32030
Billing Date: 7/10/2012
Date of Loss: 6/7/2012
5924 103.5010

Please return this portion with your remittance.

Mail Payment To:
Vectren Utilities Holding Group Inc VECTREN ENERGY DELIVERY OF INDIANA - NORTH
1239 Reliable Parkway
Chicago, IL 60686-0012
Inquiries: 1-877-902-2934, Mon.-Fri., 8-5
Risk Management/Claims Department

NOW DUE

$1,013.63

LINEAL CONTRACTING
2922 MITCHELL ROAD,
BEDFORD, IN 47421

Type: GAS
Invoice: FDS0016352
BillToID: 32030
Billing Date: 7/10/2012
Date of Loss: 6/7/2012

Invoice For Costs to Repair and Reconstruct Damaged Property

Address: 2550 E 3RD STREET, BLOOMINGTON
2" PLASTIC SERVICE SEVERED BY BORE. NOT HAND EXPOSED.

Material:	$75.99
Company Labor:	$455.94
Contract Labor:	$0.00
Transportation/Equipment:	$145.00
Misc:	$0.00
Gas Loss:	$336.70
Adjustments:	$0.00
Payments:	$0.00
Total:	$1,013.63

5924 103.5010

Remember, call two (2) working days before digging. Contact I.U.P.P.S. at 1-800-382-5544.

Form 2100 (3/02)

Vectren Corporation
Form 3112 (Rev.0711) (CIS 10/11)

FDS 0016352

Vectren Claim Number: _____

Police Report /MO #: _____

Task No: 103.0510 Capital / O &M (circle one)
Date of Damage 6 / 7 / 12
Cost Center # 5924
Time Occurred 8:38 am / pm
Time Found 8:49 am / pm
Latitude 39.14563 Longitude: -86.49765

FACILITIES DAMAGE REPORT GAS

Vectren Claims Camera:

VE01564

~~Form 2990~~

DAMAGE SITE:
Address 2550 E 3rd ST Lot #
County Monroe City Bloomington State IN Township 47403

FACILITY TYPE:
☐ Distribution ☐ Propane
☒ Service ☐ Storage
☐ Transmission: (include supplemental report)

FACILITIES DAMAGED:
☐ Farm Tap
☐ Heater
☐ Main
☐ Meter (Residential)
☐ Meter (Industrial / Commercial)
☐ Odorizer
☐ Regulator Station
☐ Relief Valve
☐ Riser
☒ Service Line
☐ Valve
☐ Other

ORIFICE SIZE(S):	(1)	(2)	(3)
0.50 inch	☐	☐	☐
5/8 inch	☐	☐	☐
0.75 inch	☐	☐	☐
1.00 inch	☐	☐	☐
1.25 inch	☐	☐	☐
2.00 inch	☒	☐	☐
3.00 inch	☐	☐	☐
4.00 inch	☐	☐	☐
5.00 inch	☐	☐	☐
6.00 inch	☐	☐	☐
10.00 inch	☐	☐	☐
12.00 inch	☐	☐	☐
16.00 inch	☐	☐	☐
20.00 inch	☐	☐	☐
Other			

1.943

VISUAL OBSERVATION AT DAMAGE SITE: 6/8

Visual Observation: ☐ Above Ground ☒ Below Ground
Locate Applicable ☒ Yes ☐ No ☐ N/S
Facilities Properly Marked ☒ Yes ☐ No ☐ N/S
Marking Methods: ☐ Conventional ☐ Flags ☐ None
☐ Offset ☒ Paint ☐ Stakes ☐ Whiskers
Locate Marking Faded: ☐ Yes ☒ No ☐ N/S
Wrong Address Requested ☐ Yes ☐ No ☐ N/S

Facilities Improperly Located:
☐ Qualified Locator Could Not Have Accurately Located
☐ Inaccurate Maps / Cards
☐ Broken or No Tracer Wire (Plastic)
☐ Insulation Preventing Accurate Locate

Locator Error:
☐ Failure to Follow Policy
☐ Inappropriate Site Markings
☐ Incomplete Locate
☐ No Locates Performed
☐ Qualified Locator Could Have Accurately Located
☐ Wrong Address Located
☐ Marking Off By: _____ (Feet / Inches)

JUL 2 2012

TYPE OF MATERIAL:
☐ Cast Iron
☐ Plastic (HDPE)
☒ Plastic (MDPE)
~~☐ Steel~~
☐ Other

DAMAGE TYPE:
☒ Severed
☐ Not Cut
☐ Severed
Size ____ x ____

PRESSURE:
☐ 25 PSIG
☐ 40 PSIG
☐ 50 PSIG
☐ 55 PSIG
☒ 60 PSIG
☐ 6 WC (.2163)
☐ 7 WC (252)
☐ Other

163230

Were Facility Marks Visible ☒ Yes ☐ No
Was Area White Lined ☐ Yes ☐ No ☐ Destroyed
Positive Response ☐ Yes ☐ No ☐ Destroyed
Tolerance Zone Violated ☐ Yes ☐ No
Part of Project ☐ Yes ☐ No
Company Representative On-Site ☐ Yes ☐ No

PROTECTION IN PLACE:
☐ Building ☐ Fence ☒ None
☐ Post ☐ Rail ☐ Vault ☐ N/A
☐ Other

DURATION OF ESCAPING GAS:
Minutes: 20 min

EFV Activated ☐ Yes ☒ No ☐ N/S

Observation by (ID#): _____

LEAK REPORT NUMBER: 10510

Number of Customers Affected: 1
Total Hours Service Was Off: 2

Name of Locator: _____

LOCATING ORGANIZATION:
☐ Contract Locator
☐ Unknown / Other
☐ Utility Owner

FEED TYPE:
☒ One-Way Feed
☐ Two-Way Feed

SERVICE ORDER NUMBER: 5271211

DAMAGED BY:
☐ Company Crew
☒ Contractor
☐ County
☐ Developer
☐ Farmer
☐ Municipality
☐ Property Owner/ Tenant
☐ Railroad
☐ State
☐ Unknown
☐ Utility
☐ Vehicle Accident
☐ Other

TYPE OF CONSTRUCTION:
☐ Agriculture
☐ Building Construction
☐ Building Demolition
☐ Cable TV
☐ Curbs / Sidewalk
☐ Drainage
☐ Driveway
☐ Electric
☐ Engineering / Surveying
☐ Fencing
☐ Grading
☐ Irrigation
☐ Landscaping
☐ Liquid Pipeline
☐ Milling
☐ Pole
☐ Natural Gas
☐ Public Transit Authority
☐ Railroad Maintenance
☒ Other Fiber Optic

NOTIFICATIONS AND OTHER DETAILS OF LOCATE:

☐ Locate Ticket: _____

Date: _____ Time: _____ am / pm

TYPE OF REQUEST:
☐ Regular Request ☐ Emergency Request
☐ Locate Company Notified
Contact Name: _____
Time Called: _____ am / pm
Time Locator Arrived at the Site: _____ am / pm

Company Notified of Locate Near Critical Facilities
☐ Yes ☐ No ☐ N/S

Copy of Mark Out Request Provided Within 2 Working Days
☐ Yes ☐ No ☐ N/S

WORKING FOR:
☐ City ☐ County ☐ Developer
☐ State ☐ Property Owner
☒ Utility AT&T

ONE-CALL CENTER:
☐ IUPPS
☐ OUPS
☐ Unknown

CONTINUE ON BACK – INCLUDE ANY OBSERVATIONS / DIAGRAMS

Vectren Claim Number: _____

TYPE OF EQUIPMENT:
- ☐ Auger
- ☐ Backhoe / Track hoe
- ☒ Boring
- ☐ Drilling
- ☐ Explosives
- ☐ Farm Equipment
- ☐ Grader / Scraper
- ☐ Hand Tools
- ☐ Milling Equipment
- ☐ Plow
- ☐ Probing Device
- ☐ Trencher
- ☐ Vacuum Equipment
- ☐ Vehicle
- ☐ Other _____

ROOT DAMAGING CAUSE:
- ☐ Abandoned Facility
- ☐ Deteriorated Facility
- ☐ Facility Could Not be Found/ Located
- ☐ Facility Was Not Located / Marked
- ☐ Failure to Maintain Clearance
- ☐ Failure to Maintain Marks
- ☐ Failure to Support Exposed Facility
- ☒ Failure to Use Hand Tools Where Required
- ☐ Improper Backfilling
- ☐ Incorrect Records / Maps
- ☐ Marking or Location Not Sufficient
- ☐ No Notification Made to One-Call
- ☐ One-Call Notification Error
- ☐ Previous Damage
- ☐ Wrong Information Provided
- ☐ Other _____

CONTRACTOR REPAIRS:
- ☐ Contractor Working for Vectren Made Repairs at Own Expense ☐ Yes ☐ No ☐ N/S
- ☐ Contractor Repaired Damage ☐ Yes ☐ No ☐ N/S

Name of Contractor: _____
# of Regular Hours; _____
# of Overtime Hours; _____
# of Regular Hours; _____
Crew Type: _____

MATERIALS OR ROAD WORK:
- ☐ Meter was replaced _____ (Stores Code)
- ☐ Regulator Was Replaced _____ (Stores Code)
- ☐ Temporary Asphalt Repair: _____ (sq. ft.)
- ☐ Permanent Asphalt Repair: _____ (sq. ft.)

Did Excavator Notify You	☐ Yes	☒ No	
Excavation Required	☒ Yes	☐ No	
Media at Site	☐ Yes	☒ No	
Was There Ignition of Gas?	☐ Yes	☒ No	
INVOICE:	☒ Yes	☐ No	☐ N/S

RIGHT OF WAY:
- ☐ Dedicated Utility Easement
- ☐ Federal Utility Easement
- ☐ Pipeline
- ☐ Power / Transmission Line
- ☐ Private - Business
- ☐ Private - Easement
- ☐ Private - Land Owner
- ☐ Public - County Road
- ☐ Public - Interstate Highway
- ☐ Public - Other
- ☐ Public - State Highway
- ☐ Public – City Street
- ☐ Unknown

DAMAGING PARTY:
Name: Lineal
Address: 2922 Mitchell Rd
City/ State/ Zip: Bedford IN
Phone: (812) 277 6457
Matt Burton — 6-7-12
Prepared / Investigated By: — Date:

PARTY TO INVOICE:
Name: Lineal
Address: 2922 Mitchell Rd
City/ State/ Zip: Bedford IN
Phone: (812) 277 6457
Randy Powers — 6/11/12
Reviewed by Field Supervisor: — Date:

DAMAGE SEE REMARKS

Ticket : 1206070515 Date: 06/07/2012 Time: 08:28 Oper: SMCCLURE Chan:092

State: IN Cnty: MONROE Twp: PERRY
Cityname: BLOOMINGTON Inside: Y Near: N
Subdivision:

Address : 2500
Street : E 3RD ST
Cross 1 : S COLLEGE MALL RD Within 1/4 mile: Y
Location: LOCATE-- THE ABOVE ADDRESS LOCATE EAST FOR APPROX 500 FEET ON THE SOUTH SIDE OF E 3RD STREET
***Boring Where = UNDER DRIVE AND UNDER 3RD ST
:
Grids : 3909A8630D 3909A8630C

Work type : INSTALL FIBER OPTIC CABLES
Done for : AT&T
Start date: 06/07/2012 Time: 08:29 Hours notice: 0/000 Priority: EMER
Ug/Oh/Both: U Blasting: N Boring: Y Railroad: N Emergency: Y
Duration : 1 WEEK Depth: 5 FEET

Company : LINEAL CONTRACTING Type: CONT
Co addr : 2922 MITCHELL ROAD
City : BEDFORD State: IN Zip: 47421
Caller : MIKE BLACKBURN Phone: (812)277-0477
Contact : BRIAN BUSICK-CELL Phone:
BestTime:
Mobile : (812)521-3474
Fax : (812)275-6706
Email : MLACKEYLCI@HOTMAIL.COM

Remarks : All tickets are taken and processed on Eastern Daylight Time
PER MIKE BLACKBURN - A VECTREN GAS LINE HAS BEEN DAMAGED - LINE IS BLOWING AND GAS CAN BE SMELLED - LINE WAS DAMAGED AT THE FRONT EASEMENT - LINE IS YELLOW AND 1/2 INCH - CREW IS ON SITE - ADVISE MIKE BLACKBURN TO CALL 911 AND VECTREN - PREVIOUS TICKET 1205082869 - THANK YOU
Will you be white-lining the dig site area? YES
:

Submitted date: 06/07/2012 Time: 08:28
Members: ID0002 ID1443 ID3147 ID3452 ID3740 ID4752 ID5960 ID8060 SBCIN SM

Member Name	Facility Types
AT&T - DISTRIBUTION	COMMUNICATIONS
BLOOMINGTON TRAFFIC DIVISION, CITY OF	TRAFFIC
BLOOMINGTON UTILITIES, CITY OF	SEWER & WATER
COMCAST CENTRAL (BLOOMINGTON)	CABLE TV
DUKE ENERGY / FORMERLY CINERGY	ELECTRIC
INDIANA UNIVERSITY - BLOOMINGTON	
SMITHVILLE TELEPHONE COMPANY, INC	TELEPHONE
VECTREN - BLOOMINGTON	GAS
WINDSTREAM KDL	COMMUNICATIONS

View Map | Close Map

SECOND NOTICE 2ND NOTICE

Ticket : 1205302980 Date: 06/01/2012 Time: 08:26 Oper: AHINES Chan:085
Old Tkt: 1205302980 Date: 05/30/2012 Time: 13:41 Oper: JSMITH Rev: 00A

State: IN Cnty: MONROE Twp: PERRY
Cityname: BLOOMINGTON Inside: Y Near: N
Subdivision:

Address :
Street : E 3RD ST
Cross 1 : S COLLEGE MALL RD Within 1/4 mile: Y
Location: FROM THE ADDRESS OF 2500 EAST 3RD STREET LOCATE GOING EAST FOR APPROX 500 FEET ON THE SOUTH SIDE OF E 3RD STREET
***Boring Where = UNDER DRIVE AND UNDER 3RD ST
:
Grids : 3909A8630D 3909A8630C

Work type : INSTALL FIBER OPTIC CABLES
Done for : ATT
Start date: 06/01/2012 Time: 14:00 Hours notice: 5/005 Priority: NORM
Ug/Oh/Both: U Blasting: N Boring: Y Railroad: N Emergency: N
Duration : 1 WEEK Depth: 5 FEET

Company : LINEAL CONTRACTING Type: CONT
Co addr : 2922 MITCHELL ROAD
City : BEDFORD State: IN Zip: 47421
Caller : RYAN SULLIVAN Phone: (812)277-0477
Contact : BRIAN BUSICK--CELL Phone:
BestTime:
Mobile : (812)521-3474
Fax : (812)275-6706
Email : MLACKEYLCI@HOTMAIL.COM

Remarks : All tickets are taken and processed on Eastern Daylight Time
PER MIKE BLACKBURN - STILL NEED ALL UTILITIES TO MARK THE PROPERTY AS REQUESTED - THANK YOU
Will you be white-lining the dig site area? YES
:

Submitted date: 06/01/2012 Time: 08:26
Members: ID0002 ID1443 ID3147 ID3452 ID3740 ID4752 ID5960 ID8060 SBCIN SM

Member Name	Facility Types
AT&T - DISTRIBUTION	COMMUNICATIONS
BLOOMINGTON TRAFFIC DIVISION, CITY OF	TRAFFIC
BLOOMINGTON UTILITIES, CITY OF	SEWER & WATER
COMCAST CENTRAL (BLOOMINGTON)	CABLE TV
DUKE ENERGY / FORMERLY CINERGY	ELECTRIC
INDIANA UNIVERSITY - BLOOMINGTON	
SMITHVILLE TELEPHONE COMPANY, INC	TELEPHONE
VECTREN - BLOOMINGTON	GAS
WINDSTREAM KDL	COMMUNICATIONS

View Map | Close Map

NORMAL NOTICE

Ticket : 1205302980 Date: 05/30/2012 Time: 13:41 Oper: JSMITH Chan:088

State: IN Cnty: MONROE Twp: PERRY
Cityname: BLOOMINGTON Inside: Y Near: N
Subdivision:

Address :
Street : E 3RD ST
Cross 1 : S COLLEGE MALL RD Within 1/4 mile: Y
Location: FROM THE ADDRESS OF 2500 EAST 3RD STREET LOCATE GOING EAST FOR APPROX 500 FEET ON THE SOUTH SIDE OF E 3RD STREET
***Boring Where = UNDER DRIVE AND UNDER 3RD ST
:
Grids : 3909A8630D 3909A8630C

Work type : INSTALL FIBER OPTIC CABLES
Done for : ATT
Start date: 06/01/2012 Time: 14:00 Hours notice: 48/048 Priority: NORM
Ug/Oh/Both: U Blasting: N Boring: Y Railroad: N Emergency: N
Duration : 1 WEEK Depth: 5 FEET

Company : LINEAL CONTRACTING Type: CONT
Co addr : 2922 MITCHELL ROAD
City : BEDFORD State: IN Zip: 47421
Caller : RYAN SULLIVAN Phone: (812)277-0477
Contact : BRIAN BUSICK--CELL Phone:
BestTime:
Mobile : (812)521-3474
Fax : (812)275-6706
Email : MLACKEYLCI@HOTMAIL.COM

Remarks : All tickets are taken and processed on Eastern Daylight Time
Will you be white-lining the dig site area? YES
:

Submitted date: 05/30/2012 Time: 13:41
Members: ID0002 ID1443 ID3147 ID3452 ID3740 ID4752 ID5960 ID8060 SBCIN SM

Member Name	Facility Types
AT&T - DISTRIBUTION	COMMUNICATIONS
BLOOMINGTON TRAFFIC DIVISION, CITY OF	TRAFFIC
BLOOMINGTON UTILITIES, CITY OF	SEWER & WATER
COMCAST CENTRAL (BLOOMINGTON)	CABLE TV
DUKE ENERGY / FORMERLY CINERGY	ELECTRIC
INDIANA UNIVERSITY - BLOOMINGTON	
SMITHVILLE TELEPHONE COMPANY, INC	TELEPHONE
VECTREN - BLOOMINGTON	GAS
WINDSTREAM KDL	COMMUNICATIONS

View Map | Close Map

NORMAL NOTICE

Ticket : 1205082869 Date: 05/08/2012 Time: 15:45 Oper: AHUNTER Chan:016

State: IN Cnty: MONROE Twp: PERRY
Cityname: BLOOMINGTON Inside: Y Near: N
Subdivision:

Address : 2500
Street : E 3RD ST
Cross 1 : S COLLEGE MALL RD Within 1/4 mile: Y
Location: LOCATE-- THE ABOVE ADDRESS LOCATE EAST FOR APPROX 500 FEET ON THE SOUTH SIDE OF E 3RD STREET
***Boring Where = UNDER DRIVE AND UNDER 3RD ST
:
Grids : 3909A8630D 3909A8630C

Work type : INSTALL FIBER OPTIC CABLES
Done for : AT&T
Start date: 05/11/2012 Time: 07:00 Hours notice: 63/048 Priority: NORM
Ug/Oh/Both: U Blasting: N Boring: Y Railroad: N Emergency: N
Duration : 1 WEEK Depth: 5 FEET

Company : LINEAL CONTRACTING Type: CONT
Co addr : 2922 MITCHELL ROAD
City : BEDFORD State: IN Zip: 47421
Caller : BRIAN BUSICK Phone: (812)277-0477
Contact : BRIAN BUSICK-CELL Phone:
BestTime:
Mobile : (812)521-3474
Fax : (812)275-6706
Email : MLACKEYLCI@HOTMAIL.COM

Remarks : All tickets are taken and processed on Eastern Daylight Time
Will you be white-lining the dig site area? YES
:

Submitted date: 05/08/2012 Time: 15:45
Members: ID0002 ID1443 ID3147 ID3452 ID3740 ID4752 ID5960 ID8060 SBCIN SM

Member Name	Facility Types
AT&T - DISTRIBUTION	COMMUNICATIONS
BLOOMINGTON TRAFFIC DIVISION, CITY OF	TRAFFIC
BLOOMINGTON UTILITIES, CITY OF	SEWER & WATER
COMCAST CENTRAL (BLOOMINGTON)	CABLE TV
DUKE ENERGY / FORMERLY CINERGY	ELECTRIC
INDIANA UNIVERSITY - BLOOMINGTON	
SMITHVILLE TELEPHONE COMPANY, INC	TELEPHONE
VECTREN - BLOOMINGTON	GAS
WINDSTREAM KDL	COMMUNICATIONS

View Map | Close Map

Service Order Status

Tuesday, July 3, 2012

Enter Service Order Number:
5271213 Go

Banner Instance: ○ CS03PROD ○ CS01PROD ◉ CS02PROD
Order Number: N5271213
Order Type: LEAK
Order Status: Completed

Customer: 008888888 - INACTIVE CUSTOMER
Prem: 5715038 - E 3RD ST & EASTLAND PLAZA

Technician: 5065 - Burton, Matt

Order Dates and Times

Need Date:	6/7/2012 8:58:00 AM
Time Created:	6/7/2012 8:39:24 AM
Time Dispatched:	6/7/2012 8:39:24 AM
Time In Route:	6/7/2012 8:40:33 AM
Time On-Site:	6/7/2012 8:50:28 AM
Tech Complete:	6/7/2012 10:22:43 AM
Time Closed:	6/7/2012 10:22:43 AM

Events Performed/Completion Code
LKNS - CMP

Meter Information

	Current ReadStatus
Old Meter:	
New Meter:	

Completion Notes
contractor bored into a 2" pl serv dist on site making repairs , ck a suroundi ng houses and business n gas in side

Request Notes
BLOWING LINE PER LARRY W/ LINEAL CONTRACTING. POSSIBLE 2". DID HAVE LOCATESLOCATE NUMBER NOT AVAILAB LE. CONT# 812-797-2189

MDSI Event Dates and Times

Event	Date/Time	User
AsnAssignmentManualAck_evt	6/7/2012 8:40:11 AM	Burton, Matt
AsnAssignmentEnRoute_evt	6/7/2012 8:40:33 AM	Burton, Matt
AsnAssignmentOnSite_evt	6/7/2012 8:50:28 AM	Burton, Matt
OrdOrderComplete_evt	6/7/2012 10:22:43 AM	Burton, Matt

NOTE:The Reporting database replicates in near real-time; it has been approximately 0 minute(s) since the last transaction replicated.

Service Order Status

Tuesday, July 3, 2012

Enter Service Order Number:
5271211 Go

Banner Instance: ○ CS03PROD ○ CS01PROD ◉ CS02PROD
Order Number: N5271211
Order Type: LEAK
Order Status: Completed

Customer: 600135092 - UBIQUITEL
Prem: 5186777 - 2500 E 3RD ST

Technician: 5065 - Burton, Matt

Order Dates and Times

Need Date:	6/7/2012 8:58:00 AM
Time Created:	6/7/2012 8:37:47 AM
Time Dispatched:	6/7/2012 8:40:06 AM
Time In Route:	6/7/2012 10:22:48 AM
Time On-Site:	6/7/2012 10:22:51 AM
Tech Complete:	6/7/2012 10:25:12 AM
Time Closed:	6/7/2012 10:25:12 AM

Events Performed/Completion Code
LKOT - CMP

Meter Information

		Current ReadStatus
Old Meter:	5337	Active
New Meter:		

Completion Notes
dist on site making repairs no gas in surrounding buildings

Request Notes
PER AMBER WITH 811 LINEAL CONTRACTING HAS HIT A GAS LINE/ 1/2 INCH LINE/LOCATES WERE DONE 1205082869 / LINE IS BLOWING/ XST S COLLEGE MALL RD/POC BRIAN 812-521-3474/NO GAS ENT BLDGS REPORTED/

MDSI Event Dates and Times

Event	Date/Time	User
AsnAssignmentManualAck_evt	6/7/2012 8:49:29 AM	Burton, Matt
AsnAssignmentEnRoute_evt	6/7/2012 10:22:48 AM	Burton, Matt
AsnAssignmentOnSite_evt	6/7/2012 10:22:51 AM	Burton, Matt
OrdOrderComplete_evt	6/7/2012 10:25:12 AM	Burton, Matt

NOTE:The Reporting database replicates in near real-time; it has been approximately 0 minute(s) since the last transaction replicated.

DAMAGE INFORMATION REPORT – PIPELINE SAFETY DIVISION

State Form 54122 (R2 / 7-11)
INDIANA UTILITY REGULATORY COMMISSION

Submitted to IURC-Pipeline Safety on: July 17, 2012

Who is submitting this information?

Name of person providing this information: Ryan Sullivan

Business address *(number and street)*: 2922 Mitchell Road

City, State, and ZIP code: Bedford, IN 47421

Telephone number *(area code)*: 812-277-0477

Fax number *(area code)*: 812-275-6706

E-mail address: ryan@linealcontracting.com CC: jayne@linealcontracting.com

Excavator Information, if known

Full name: Lineal Contracting, INC

Business address *(number and street)*: 2922 Mitchell Road

City, State, and ZIP code: Bedford, IN 47421

Telephone number *(area code)*: 812-277-0477

Fax number *(area code)*: 812-275-6706

E-mail address: ryan@linealcontracting.com CC: jayne@linealcontracting.com

Excavation or Demolition Information

Excavator type: Contractor

Excavation or demolition equipment: Boring

Type of work performed: Telecommunications

Date and Location of Damage

Date of damage (*month, day, year*): June 7, 2012

County: Monroe

City: Bloomington

Street address (*number and street, city, state, and ZIP code*):
2550 3rd Street, Bloomington, IN 47403

Nearest intersection: _____

Right of way where damage occurred: Public - Other

Was there a release of product? Yes

If yes, was there an ignition of product? No

Were evacuations necessary as a result of release? No

If yes, how many evacuated? _____

Was there a customer service interruption? Yes

If yes, how many affected? _____

Time to restore service (*in hours*): _____

Enter number of injuries, if applicable and known: _____

Enter number of fatalities, if applicable and known: _____

Property damage, Estimate $_____

Affected Facility Information

What type of pipeline was damaged? Natural Gas

What was the affected facility? Distribution

What was the depth of the facility, in inches? _____

Notification, Locating, Marking

Did excavator request locates prior to commencing work? Yes

Enter Indiana 811 ticket number, if known: 1205082869

Was the locate request completed within two working days? Yes

If locates were performed, were they done so by a contractor or pipeline employee? Contract Locator

If a contractor locator, enter the company name, if known: USIC

Were facility marks visible in the area of excavation? Yes

Were facilities marked correctly? Yes

Type of markings used: Paint and Flags

If other, please specify: _____

Was site marked by "White Lining"? Yes

Were special instructions part of the locate request? Unknown/Other

Were maps used to complete the locate request? Unknown/Other

Were pipeline company representatives on site during excavation? No

Did the excavator notify the operator in the event of this damage? Yes

Did the excavator notify Indiana 811 in the event of this damage? Yes

Did the excavator notify 911 in the event of a release of product? Unknown/Other

Description of Cause

Select from the list the most accurate cause for the damage: Other

Additional Comments

Human error