

From: noreply@formstack.com
To: [Fire Prevention and Building and Safety Commission](#)
Subject: Code Comments, Proposals and Advice
Date: Monday, May 10, 2021 1:03:10 PM

**** This is an EXTERNAL email. Exercise caution. DO NOT open attachments or click links from unknown senders or unexpected email. ****



Formstack Submission For: **4202**

Submitted at 05/10/21 1:03 PM

Name:	David Mauser
Email:	dmauser@frpinc.com
Phone:	(317) 872-8400
Address:	9449 Priority Way West Drive Suite 200 Indianapolis, IN 46240
Indiana Code You Are Commenting On:	2014 Indiana Building Code

Comment or Proposal:

The 2014 Indiana Building Code adopts the 2012 IBC with the noted exceptions/revisions. The 2012 IBC references material design codes which are several versions behind the current codes. For concrete, the ACI 318 Code was completely reformatted in the 2014 version, but IBC 2012 references ACI 318-11. Indiana is lagging behind in all of the latest codes. There are numerous additions and revisions in the newer material design codes which currently do not apply by the 2014 Indiana Building Code's reference to IBC 2012. Therefore I would highly encourage the Committee/Commission to update the Indiana Building

Code to reference the 2021 IBC.

File:

Copyright © 2021 Formstack, LLC. All rights reserved. This is a customer service email.

Formstack, 11671 Lantern Road, Suite 300, Fishers, IN 46038