

Stormwater Board Agenda

When: 7-16-2024

Time: 4:00pm

Where: Commissioners Conference Room

Pine View Government Center

Welcome:

New Business:

2880, 2860 N. Luther Rd. - Copas Homes - FCO-2019-25 Violation

Public Comment:

ADA Notice: Floyd County, will upon request, provide appropriate aids and services leading to effective communications for qualified persons with disabilities so that they can participate equally in Floyd County's public meetings.

For special accommodations for a meeting contact the Commissioners Administrative Assistant Suzanna Worrall at

812-948-5466 or sworrall@floydcounty.in.gov at least two (2) business days prior to the scheduled meeting or event to request an accommodation.

Chris Moore

From:

Horacio Urieta

Sent:

Tuesday, July 9, 2024 2:50 PM

To:

Lesa Copas; Chris Moore

Cc:

Al Knable; Nick Creevy; Jason Sharp; John Schellenberger; Don Lopp; John G. Brinkworth, III; William Prifogle; Robert Burk; Ronnie Tuell; Cameron Voyles

Subject:

RE: Storm water and silt in front of mailbox again!

Good afternoon, Mr. Copas,

It was great to see you at the construction site this afternoon. As I mentioned to you before as well as today, we are agree from day one that stormwater and runoff at and from the construction site is an issue and it is has been an issue for several years. What is different now is all the silt coming out from the uncover ground that is eroded out and migrate to the existing ditches and the road. This situation, show us a really poor construction site management practice. Since the erosion at the site has not been controlled professionally, it has filled up the existing ditch along the road and goes to the road itself. So, excuses for the road not having a ditch line is not accepted, since it was there but now is filled up with mud and silt. Likewise. the existing driveway for ingress and egress to the site is very poor constructed and needs more rocks/gravel to prevent your vehicle carrying mud to the road as well. The requested pipe to be placed at the second entrance has not been installed yet. The existing pipe at the driveway entrance has a not been properly installed for drainage, it needs to be placed properly.

Mr. Copas, you have been notified about the situation in several occasions, can you please take care of all these issues? It is my intention to request to the Stormwater Board a STOP WORK order to be set in place until you take care of all of the county concern expressed to you on this e-mail and previous e-mails.

Should you have any question, do not hesitate to let us know.

Sincerely,

Horacio Urieta, PE.
Floyd County Engineer
Director of Highway and Public Works
2524 Corydon Pike Suite 202
New Albany, Indiana 47150

Office: 812-948-5441 Cell: 812-725-3786

From: Horacio Urieta

Sent: Thursday, May 23, 2024 3:24 PM

2880 N LUTHER ROAD



MAY 08, 2024