Retail Food Inspection Report

Floyd County Health Department
Telephone (812) 948-4726

Establishment Name	Telephone Number	Date of Inspection	ID#
DOG HAUS BIERGARTEN	Est 812-900-7677	05/29/2024	
Address 415 BANK ST, NEW ALBANY IN 47150	Own 502-376-5933		

Owner	Purpose	Follow Up	Released
DERBY CITY DOGS - NEW ALBANY LLC	X Routine		
Owner's Address 5601 ST MARY RD FLOYDS KNOBS, IN 47119	___ Follow-up		
Person in Charge	___ Complaint		
	___ Pre-Operational		
Responsible Person's Email JON.RIDDLE@DOGHAUS.COM	___ Temporary	**Menu Type**	
	___ HACCP	1 __ 2 __ 3 __ 4 X 5 __	
Certified Food Handler JON RIDDLE	___ Other (list)		

CRITICAL ITEMS ARE IDENTIFIED IN THE CHECKLIST AND NARRATIVE COLUMNS MARKED "C"
VIOLATION(S) REPEATED FROM PREVIOUS INSPECTIONS ARE DENOTED IN THE "SUMMARY OF VIOLATIONS" AND IN THE NARRAIVE COLUMN MARKED AS "R"

Section #	C	NC	R	Narrative	To Be Corrected
334	X			Observed a chemical dispenser hooked up to a mop sink faucet that was left on. The backflow valve on the faucet is not designed for constant pressure. Turn off faucet and release pressure after each use or install a bleeder T valve.	Retrain/Corrected
352		X		Observed the restroom door near the patio missing a self-closer.	6-19-24

Summary of Violations C 1 NC 1 R 0 2

Received by (name and title printed):	Inspected by (name and title printed):
JON RIDDLE	Thomas Snider CFS
Received by (signature):	Inspected by (signature):

cc:	cc:	cc: