

Date:12/02/2024

**Addendum No. 2**

**For Project No. ENG2303730652  
Lincoln SP Phase 5 – Park Entry Improvements  
Lincoln State Park  
Spencer County**

**ISSUED FROM: Engineering Division Dept. Natural Resources**

**ISSUE DATE: December 2, 2024**

**BID DATE: December 10, 2024**

**FOR AGENCY: Department of Natural Resources**

**The information contained in this Addendum shall become a part of the basic plans and specifications the same as if original incorporated therein. The original plans and specifications shall remain in their entirety, except as modified by this Addendum. The items herein shall supersede information in the specifications and on the plans.**

**ITEM No. 1: GENERAL**

- A. Attached clarifications to the drawings and specifications dated 11-25-24.

**Addendum #2**

Lincoln Amphitheater – Phase 5 – Park Entry Improvements  
Lincoln City, IN  
LA23102


11-25-24

---

This addendum is to become a part of the Contract Documents and shall be properly acknowledged and dated on the Bid Form by the Bidding Contractor.

1. The contractor is to remove the AT&T communications pedestal from the site. No relocation is required.
2. Relative to line striping, no "STOP" bar is required at the intersection.
3. Clarification: Yellow center line and White lane line striping along with pavement paint directional arrows shown on the plans shall be included in Base Bid as noted on the plans on sheet C201. Lines and arrows shall be painted regardless of acceptance of Alternate Bid 1 Add for overlay paving.
4. Clarification - Sheet C501 Details Base Bid: Delete the Thermo-Plastic Pavement Marking Paint Specification from the sheet and replace with: "Standard Pavement Marking Paint Specification: All pavement paint lines and arrows shall be Low VOC Acrylic traffic marking paint, colors as specified, complying with FS TT-P-1952."

UNIVERSAL DESIGN ASSOCIATES, INC.



Bethany S. Hopf, PE  
Civil Engineer

