

Date:01/09/2025

Addendum No. 1 REBID

**For Project No. ENG2503758164
Lift Station Rehab Miami SRA
Mississinewa Lake
Wabash & Miami Counties**

ISSUED FROM: Engineering Division Dept. Natural Resources

ISSUE DATE: January 09, 2025

REBID DATE: February 13, 2025

FOR AGENCY: Department of Natural Resources

The information contained in this Addendum shall become a part of the basic plans and specifications the same as if original incorporated therein. The original plans and specifications shall remain in their entirety, except as modified by this Addendum. The items herein shall supersede information in the specifications and on the plans.

ITEM No. 1: GENERAL

A. Attached, please find a summary of clarifications.

ITEM No. 2: CONSTRUCTION PLANS

N/A

ITEM No. 3: SPECIFICATIONS

N/A

END OF ADDENDUM

State Form 21208R4

DAPW-118

Mississinewa Lift Station Rehab Miami SRA

Mississinewa Lake and Miami SRA

DEPARTMENT OF NATURAL RESOURCES

STATE OF INDIANA

Public Works Project No. ENG2503758164

Summary of REBID Clarifications:

1. The Instructions to Bidders, Section 04, Part I provides information on bid bond requirements. Bidders are encouraged to thoroughly review and comply with all bid documents to avoid issues with bid acceptance.
2. Regarding system integration, the previous SCADA service provider was Rockwell.
3. Bidders are responsible for field verifying all existing conditions and providing and installing all items necessary for a fully functional, turn-key project.
4. Normal working hours may be adjusted as approved by the Property Manager.
5. The Property has limited security patrols during the specified project period. Project site security shall be the responsibility of the Contractor.
6. Assistant Manager and Service Area Lift Station:
 - a) Provide galvanized or brass fittings for pipe connections.
 - b) The location of the existing water line stub out is visible.
 - c) Provide #12 copper locate wire and as required for underground utilities.
 - d) The new control panel for the new lift station shall remain located on the adjacent building.
 - e) The proposed location of the new sewage pit package is inside the existing pole barn. Installation of the waterline to this room within the pole barn and installation of the new sewage line from the new sewage pit package to the new lift station shall take into consideration the existing pole barn construction, which includes a rat trench approximately 2' deep.
 - f) At Bidder's option, provide new NEMA 4X rated stainless steel enclosure with factory wired control panel rather than field installation of new control panel within reused existing enclosure. All unused enclosures shall be returned to Owner.
 - g) Provide and install pedestal base for mobile Davit crane. Mount base as required to existing concrete structure to accommodate applicable loads and safety factor required.
7. Miami Ramp Lift Station:
 - a) The battery backup system shall provide 2-hours (minimum) of PLC and SCADA operation.
 - b) Control panel scope shall include a new button to reverse the pump motor.
 - c) Provide PLC's with hand control backup and as required by IDEM.

- d) Special disconnects for equipment removal prior to flood event(s) not required.
- e) Provide and install pedestal base for mobile Davit crane. Mount base as required to existing concrete structure to accommodate applicable loads and safety factor required.

8. Miami Campground Lift Station:

- a) The battery backup system shall provide 2-hours (minimum) of PLC and SCADA operation.
- b) Control panel scope shall include a new button to reverse the pump motor.
- c) Provide PLC's with hand control backup and as required by IDEM.
- d) The portable Davit crane shall be sized to remove the maximum pump weight at any of the project locations and include an electric winch that can be plugged into each of the control panels. Crane shall have epoxy finish.
- e) Provide and install pedestal base for mobile Davit crane. Mount base as required to existing concrete structure to accommodate applicable loads and safety factor required.
- f) Guide brackets shall be stainless steel.

9. Seasonal Campground Front Lift Station:

- a) The battery backup system shall provide 2-hours (minimum) of PLC and SCADA operation.
- b) Control panel scope shall include a new button to reverse the pump motor.
- c) Provide PLC's with hand control backup and as required by IDEM.
- d) Provide and install pedestal base for mobile Davit crane. Mount base as required to existing concrete structure to accommodate applicable loads and safety factor required.

10. Miami Beach Lift Station:

- a) The battery backup system shall provide 2-hours (minimum) of PLC and SCADA operation.
- b) Control panel scope shall include a new button to reverse the pump motor.
- c) Provide PLC's with hand control backup and as required by IDEM.
- d) Provide and install pedestal base for mobile Davit crane. Mount base as required to existing concrete structure to accommodate applicable loads and safety factor required.

Thank you for supporting the Department of Natural Resources!

DNR is committed to the wise use of the state's resources *and* our tax dollars.

As directed by State of Indiana procurement laws and Indiana Department of Administration (IDOA) policy, all entities ("suppliers") conducting business with DNR must be registered before we can finalize a solicitation award, create a purchase order, execute a contract, or make a payment.

WE GET IT: Doing business with the State can seem overwhelming.

Assistance is available through IDOA's *Vendor and Supplier Resource Center* at <https://www.in.gov/idoa/3106.htm>.

You'll also find registration forms and links, as well as detailed information on State bidding opportunities, purchasing terminology, supplier responsibilities, technical support, and more.

Communicating with DNR is easy.

Because DNR divisions and properties make their own procurement decisions, communicating directly with them about your products and services is best. Contact information is available on DNR's website at <https://www.in.gov/dnr/>.

Additionally, the DNR Division of Purchasing is happy to distribute electronic information on your behalf. Feel free to email your request to DNRPurchase@dnr.in.gov.

REGISTRATIONS TO BE A STATE SUPPLIER

1. Auditor of State (AOS)

Required for all suppliers, payments, and dollar amounts.

Complete the two forms listed below to create a new account, update an inactive account, or modify information on an existing account (e.g. address, bank account, business name). Submit completed forms to your DNR contact person OR email them directly to DNRVendorForms@dnr.in.gov.

- **Request for Taxpayer Identification Number and Certification** (IRS W-9, October 2018)
- **Automated Direct Deposit Authorization Agreement** (State Form 47551; R7/5-18)

2. IDOA Bidder Profile

Required for purchases costing \$1,500 or more and creation of a purchase order, grant, or contract, even if not technically "bidding" for anything. Upon registration, suppliers receive a unique ID which allows DNR to select them for purchase orders and payments. Suppliers can also complete information in their Bidder Profile to identify to the State what kind of business they are or products they sell.

3. Secretary of State (SOS) Business Registration

Except for Sole Proprietorships and General Partnerships, suppliers must register per IC 23-1-49-1 for purchases costing \$1,500 or more and creation of a purchase order, grant, or contract. Suppliers may not need to register for a one-time purchase.

Indiana businesses are likely already registered. Out-of-state suppliers may need to register and/or secure an Indiana agent. Initial registration costs \$90, with a \$30 fee every two years to remain current. Contact the SOS for detailed advice.

4. Tax Clearances

DNR cannot issue a purchase order to or execute an agreement with a supplier who owes taxes to the State of Indiana. Suppliers must be current with all tax payments to the Indiana Department of Revenue (<https://www.in.gov/dor/>) and the Indiana Department of Workforce Development (<https://www.in.gov/dwd/>). DNR cannot provide tax-related information or advice.