

910-M-068 MSE RETAINING WALL REINFORCEMENT CHANGES

(Adopted 07-20-23)

The Standard Specifications are revised as follows:

SECTION 910, BEGIN LINE 508, INSERT AS FOLLOWS:

Ground-reinforcement units shall be hot rolled from bars to the required shape and dimensions. Physical and mechanical properties of the units shall be in accordance with ASTM A572, grade 60 or 65. Tie strips shall be shop fabricated with hot-rolled steel in accordance with the minimum requirements of ASTM A1011, grade 50. Galvanization for ground-reinforcing units and tie strips shall be in accordance with ASTM A123, coating grade 85, for strip-type reinforcements or ASTM A641, class 5 or class C, for bar mat or grid-type reinforcements.
