

DEPARTMENT OF HEALTH AND HUMAN SERVICES  
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 05/16/2024  
FORM APPROVED  
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  <b>15G175</b>	(X2) MULTIPLE CONSTRUCTION A. BUILDING <b>02</b>  B. WING _____		(X3) DATE SURVEY COMPLETED  <b>R</b> <b>05/14/2024</b>
NAME OF PROVIDER OR SUPPLIER  <b>RES CARE COMMUNITY ALTERNATIVES SE IN</b>			STREET ADDRESS, CITY, STATE, ZIP CODE <b>3607 MIDDLE RD</b> <b>JEFFERSONVILLE, IN 47130</b>		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
{E 000}	Initial Comments  A Post Survey Revisit (PSR) to the Post Survey Revisit (PSR) conducted on 04/04/2024 to the Emergency Preparedness Survey conducted on 02/15/2024 was conducted by the Indiana Department of Health in accordance with 42 CFR 483.475.  Survey Date: 05/14/2024  Facility Number: 000709 Provider Number: 15G175 AIM Number: 100243190  At this Post Survey Revisit, Res Care Community Alternatives SE In was found in compliance with Emergency Preparedness Requirements for Medicare and Medicaid Participating Providers and Suppliers, 42 CFR 483.475  The facility has 7 certified beds. At the time of the survey, the census was 6.  Quality Review completed on 05/15/24	{E 000}			
{K 000}	INITIAL COMMENTS  A Post Survey Revisit (PSR) to the Post Survey Revisit which exited on 04/04/2024 to the Life Safety Code Recertification Survey conducted on 02/15/2024 was conducted by the Indiana Department of Health in accordance with 42 CFR 483.470(j).  Survey Date: 05/14/2024  Facility Number: 000709 Provider Number: 15G175 AIM Number: 100243190	{K 000}			

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Any deficiency statement ending with an asterisk (\*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

DEPARTMENT OF HEALTH AND HUMAN SERVICES  
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 05/16/2024  
FORM APPROVED  
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  <b>15G175</b>	(X2) MULTIPLE CONSTRUCTION A. BUILDING <b>02</b>  B. WING _____		(X3) DATE SURVEY COMPLETED  <b>R</b> <b>05/14/2024</b>
NAME OF PROVIDER OR SUPPLIER  <b>RES CARE COMMUNITY ALTERNATIVES SE IN</b>			STREET ADDRESS, CITY, STATE, ZIP CODE <b>3607 MIDDLE RD</b> <b>JEFFERSONVILLE, IN 47130</b>		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
{K 000}	Continued From page 1  At this Life Safety Code survey, Res Care Community Alternatives SE In was found in compliance with Requirements for Participation in Medicaid, 42 CFR Subpart 483.470(j), Life Safety from Fire and the 2012 Edition of the National Fire Protection Association (NFPA) 101, Life Safety Code (LSC), Chapter 33, Existing Residential Board and Care Occupancies.  This two story building was determined to be fully sprinklered. The facility has a fire alarm system with smoke detection in corridors and in all living areas. The facility has heat detectors installed in the attic. The facility has a capacity of 7 and had a census of 6 at the time of this survey.  Calculation of the Evacuation Difficulty Score (E-Score) using NFPA 101A, Alternative Approaches to Life Safety, Chapter 6, rated the facility Slow with an E-Score of 4.32.  Quality Review completed on 05/15/24	{K 000}			