

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 08/29/2024
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 155662	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING _____	(X3) DATE SURVEY COMPLETED R 08/27/2024
--	---	--	---

NAME OF PROVIDER OR SUPPLIER REHABILITATION CENTER AT HARTSFIELD VILLAGE	STREET ADDRESS, CITY, STATE, ZIP CODE 503 OTIS R BOWEN DR MUNSTER, IN 46321
--	---

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
--------------------	--	---------------	---	----------------------

{K 000}	<p>INITIAL COMMENTS</p> <p>A Post Survey Revisit (PSR) to the Life Safety Code Recertification and State Licensure Survey conducted on 07/01/24 was conducted by the Indiana Department of Health in accordance 42 CFR Subpart 483.90(a).</p> <p>Survey Date: 08/27/24</p> <p>Facility Number: 010758 Provider Number: 155662 AIM Number: 200229550</p> <p>At this Life Safety Code PSR, Rehabilitation Center at Hartsfield Village was found in compliance with Requirements for Participation in Medicare/Medicaid, 42 CFR Subpart 483.90(a), Life Safety from Fire and the 2012 edition of the National Fire Protection Association (NFPA) 101, Life Safety Code (LSC), and 410 IAC 16.2. The building was surveyed with Chapter 19, Existing Health Care Occupancies.</p> <p>The facility is a two story building with a one story section and a partial basement. The one story section is Type II (000) construction and the two story building is of Type II (111) construction. Because the one story and two sections of the building are not separated by two hour rated construction, the building is considered one building of Type II (000) construction. The building is fully sprinklered with supervised smoke detectors on all levels including in corridors, in resident rooms, and in areas open to the corridor. The building is protected by a 400 kW diesel powered emergency generator The facility has the capacity for 112 and had a census of 97 at the time of this survey.</p>	{K 000}		
---------	---	---------	--	--

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE	TITLE	(X6) DATE
---	-------	-----------

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 08/29/2024
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 155662	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED R 08/27/2024
NAME OF PROVIDER OR SUPPLIER REHABILITATION CENTER AT HARTSFIELD VILLAGE		STREET ADDRESS, CITY, STATE, ZIP CODE 503 OTIS R BOWEN DR MUNSTER, IN 46321		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
{K 000}	Continued From page 1 All areas where the residents have customary access were sprinklered and all areas providing facility services were sprinklered. Quality Review completed on 08/28/24	{K 000}		