



*ISO 9001:2015  
AS 9100D  
ISO 14001:2015  
ISO 13485  
NADCAP*

# Water Reuse Program July 2024-2025



# WATER REUSE STUDY

SAMPLE POINT →	Final Outfall (Waste Water)	Counterflow Stage 1 (Copper Plate)	Counterflow Stage 1 (Nickel)	Counterflow Stage 1 (Chrome)	Boiler Water Blow Down	Cooling Tower Blow Down
SAMPLE COMPONENT ↓						
A) Conductivity:						
B) Total Dissolved Solids:						
C) Total Chlorides:						
D) Total Sulfates:						
E) Alkalinity:						
F) Carbonates:						
G) Hardness:						



- ▶ South Carolina facility added an auto plating line 28 tanks at 176gls/tank. The line contains 14 process tanks and 14 rinses.
- ▶ The rinse tanks run at 0.25gl/minute water flow allowing approximately 2,100 gallons of water per 10 hour shift.





- ▶ The cost of water at \$15.00 per thousand gallons makes it sound like it would not be profitable to reuse the rinse water. The issue is not the cost of the city water but the cost to waste treat and discharge the rinse water.
- ▶ The Lexington SC facility to discharge treated wastewater to the Cayce POTW our facility spends \$0.03/gl on surcharges before we have even treated the water.
- ▶  $2100 \text{ gallons/day} \times .03 = \$63.00/\text{day} \times 250 \text{ days} = \$15,750.00 \text{ savings.}$



- ▶ What do we do?
- ▶ Run a water profile
- ▶ Check for items Jim Collins stated on his water study.



Cations	Total mg/L ion	Dissolved mg/L ion	Anions	mg/L ion	
Aluminum (Al <sup>+3</sup> )	BDL	BDL	Chloride (Cl <sup>-1</sup> )	NA	
Barium (Ba <sup>+2</sup> )	BDL	BDL	Chromium (Cr <sup>+6</sup> )	NA	
Beryllium (Be <sup>+2</sup> )	BDL	BDL	Fluoride (F <sup>-1</sup> )	NA	
Cadmium (Cd <sup>+2</sup> )	BDL	BDL	Nitrate (NO <sub>3</sub> <sup>-1</sup> )	NA	
Calcium (Ca <sup>+2</sup> )	BDL	BDL	Phosphate (PO <sub>4</sub> <sup>-3</sup> )	NA	
Chromium (Cr <sup>Total</sup> )	BDL	BDL	Sulfate (SO <sub>4</sub> <sup>-2</sup> )	NA	
Cobalt (Co <sup>+2</sup> )	BDL	BDL			
Copper (Cu <sup>+2</sup> )	2.36	2.31	Other Parameters		
Iron (Fe <sup>+3</sup> )	BDL	BDL	pH	2.20	electrometric
Lead (Pb <sup>+2</sup> )	0.860	0.86	Conductivity	9,340	µS/cm
Magnesium (Mg <sup>+2</sup> )	BDL	BDL	TOC	na	mg/L
Manganese (Mn <sup>+2</sup> )	BDL	BDL	Total Mercury (Hg <sup>+2</sup> )	BDL	µg/L
Nickel (Ni <sup>+2</sup> )	74.4	72.1	Dissolved Mercury	BDL	µg/L
Potassium (K <sup>+1</sup> )	13.7	13.7	TSS	3	mg/L
Silver (Ag <sup>+1</sup> )	BDL	BDL	Color	Clear	visual
Sodium (Na <sup>+1</sup> )	28.9	28.9	Cyanide (CN)	NA	Spot
Thallium (Tl <sup>+2</sup> )	BDL	BDL	Ferricyanide (Fe[CN] <sub>6</sub> )	NA	Spot
Titanium (Ti <sup>+2</sup> )	BDL	BDL	Odor	None	
Tin (Sn <sup>+2</sup> )	BDL	BDL			
Zinc (Zn <sup>+2</sup> )	1.53	1.53	1) Treatment Goal: Water Reuse.		
			2) Treatment Flow: 3gpm, 20hrs/day, 4days/week.		
Arsenic (As)	BDL	BDL	3) Media Usage Estimate:		
Antimony (Sb)	BDL	BDL	- 130 gallons per 3.6ft <sup>3</sup> MB1 tank.		
Molybdenum (Mo)	BDL	BDL	4) Sample too concentrated for WWIX recovery.		
Selenium (Se)	BDL	BDL			
Silicon (Si)	BDL	BDL			
Vanadium (V)	BDL	BDL			
Free Mineral Acidity	NA	mg/L CaCO <sub>3</sub>			
Total Acidity	NA	mg/L CaCO <sub>3</sub>			
Free Carbon Dioxide (CO <sub>2</sub> )	NA	mg/L CaCO <sub>3</sub>			
NOTES:					
BDL = Below Detection Limit					
NA = Not Analyzed					
POS = Positive Spot					
NEG = Negative Spot					



- ▶ Metals good for recycling with Ion Exchange from plating line.
- ▶ Chlorides, sulfides, TDS among other things are good.
- ▶ Conductivity???
- ▶ Ion exchange will not work.
- ▶ What do we do now?





- ▶ Short term and long term solution.
- ▶ Short term electrolysis.
- ▶ This has allowed us to remove the metals and with a pH adjust and remove WWT cost.





- ▶ Long Term
- ▶ R/O after WWT to eliminate 95% of water going to the POTW. This will be completed by spring 2025.
- ▶ Why would you only eliminate 95% ?
- ▶ Minimum discharge amount and R/O discharge water.



- ▶ R/O system on final Discharge Water.





- ▶ This will allow our discharge of treated WWT to go from 8,000gls/day to 1,000gls/day. (POTW minimum amount and R/O discharge water)
- ▶ This will allow us a savings of \$52,500 and we will reuse the purified discharge water.

# Questions?

