

Deer Creek Campground 2023 and 2024 Water Testing Results

Sampling Date (Reported in ppm)

Parameter	EPA Standard [ppm]	04.15.23	07.25.23	08.27.24
pH	6.5 - 8.5	6.5	6.5	6.5
Hardness	10 - 100	25	>475	>475
H ₂ S	0	0	0	0
Iron (Fe)	0.3	0.3	0	0
Copper (Cu)	1.3	0.2	0.5	0.5
Lead (Pb)	0.015	0	0.005	0.015
Manganese (Mn)	0.05	0	0	0
Cl	4	5	5	3
Mercury (Hg)	0.002	0	0	0
T Nitrates	10	0	0	0
T Nitrites	1	0	0	0
Sulfate (SO ₄)	250	0	0	200
Zinc (Zn)	5	5	0	0
Fluoride (Fl)	4	4	0	0
CL ⁻	250	0	0	0
Total Alkalinity	75 - 150	80	0	240
T Coliiform	0	0	0	0
e. Coli	0	0	0	0
VOC	0	0	NA	NA
Arsenic (As)	0.015	0	NA	NA
Cadmium (Cd)	0.005	0	NA	NA
Chromium (CR)*	0.05	0	NA	NA
*EPA Considers total Cr to be all Cr VI				